

The logo for CADEM SOFTWARES features a stylized blue 'C' icon on the left, composed of two curved segments. To its right, the words 'CADEM SOFTWARES' are written in a bold, blue, sans-serif font.

CADEM SOFTWARES

www.cadem.net
enquiry@cadem.net

 **www.cadem.net/facebook**

 **www.cadem.net/youtube**

 **www.cadem.net/linkedin**

 **www.cadem.net/googleplus**

 **www.cadem.net/twitter**

CademPVD

Software for the Mechanical Design of Process Equipment

Equipment design experience since 1987 captured, polished and ready for transfer to designers, fabricators and plant engineers.

- **Intelligent, works with minimum inputs**
- **Generates final designs at estimation stage**
- **Saves costing and quotation making time**
- **High quality documentation with all formulae and relevant code clauses**
- **Time tested, proven & established**

Pressure Vessels
Reaction Vessels
Agitator Shafts
Heat Exchangers
Process Columns
Storage Tank
Floating Roof
Chimney

ASME Sec. VIII Div. 1
TEMA
IS 2825
EN 13445
EEUA
API 650
API 620
IS 6533

“CademPVD” is an integrated software encompassing all aspects of mechanical design of various process plant equipment. It is a very intelligent software and works with minimum inputs. For any data that is not provided by the user, the software uses the best possible estimates for them wherever possible. This makes the software very easy to use, thus greatly enhancing equipment design productivity.

eg: For a body flange of an equipment, none of the parameters like the Flange OD, Flange ID, PCD, Number and Size of bolts, Gasket OD & ID, etc. need to be specified. The software evaluates all these undefined parameters by itself, meeting the requirements of the specified equipment design code.

The software performs intricate calculations like design of tube plates, at just the click of a button, even for multiple design conditions.

In the software, the user defines the main features of the equipment. Any changes to the features of the model are automatically reflected in all other dependent components.

The software provides detailed design calculations with relevant code clauses and formulae. This facilitates easy obtaining of approvals. This high quality documentation supports ISO and other certification processes at the customer’s end.

FREE 30 DAY TRIAL AVAILABLE ON OUR WEBSITE www.cadem.net.

Simplify

Mechanical Design

Cost Estimation

Design Documentation



Enhancing your business strength and design capabilities.

Office No. 19, SC-1 Building,
Kohinoor Estate, Wakdewadi,
Pune-Mumbai Road, Pune 411003
Pune, Maharashtra, INDIA

Phone: +91 20 46300036
Email: software@cadem.net
Website: www.cadem.net

Engineering Services

Extensive Experience and Excellence in Plant Engineering since 1987.

In-depth Experience in

- International and National Design Codes
- Chemical, Petrochemical, Food, Dairy, Power Plants
- Dealing with Third Party Inspection Agencies

Design of Process Equipment
Preparation of Detailed Fabrication Drawings
Design and Drawing Review
Power Plant and High Pressure Steam Piping Engineering

Pipe Stress Analysis
Structure Analysis and Design
Wind and Seismic Analysis
Finite Element Analysis

Preparation of Plot Plans
Preparation of Equipment Layouts
Piping Engineering and Designing
3D Models and Walkthroughs
Isometrics and BOM

We are an organization engaged in design of Process Equipment, Piping Engineering and Engineering Software development since 1987.

Our flagship software product, CademPVD, encompasses all aspects of mechanical design of shell and tube heat exchangers, pressure vessels, self supported columns and chimneys etc.

We undertake design and preparation of fabrication drawings for pressure vessels, reactors with agitator shafts, heat exchangers, storage tanks, tall towers, chimneys etc. as per various international and national codes like ASME Sec. VIII Div. I, TEMA, API 620, API 650, IS 2825, IS 803, IS 6533 etc.

We have wide experience in the field of detailed piping engineering of chemical, petrochemical, dairy & brewery plants. As part of piping engineering, we undertake preparation of plot plans, equipment layouts for process plants, utilities, tankfarms, piping layouts, isometrics, piping stress analysis, bill of materials, statutory requirements like factory inspector, IBR, CCOE drawings; and valve, piping, special materials specifications, stress analysis etc.

Servicing

Plant Owners
Consultants
Fabricators



Enhancing your business strength and design capabilities.

Office No. 19, SC-1 Building,
Kohinoor Estate, Wakdewadi,
Pune-Mumbai Road, Pune 411003
Pune, Maharashtra, INDIA

Phone: +91 20 46300036
Email: services@cadem.net
Website: www.cadem.net

EXAMPLE NO. PV-01

DESIGN OF PRESSURE VESSEL (GAS FILTER)

This example covers design of a simple pressure vessel. This pressure vessel has a top flat cover and a bottom dished end. The top cover is of bolted type and is connected to the shell through top body flange. The pressure vessel is provided with lugs support and lifting lug.

'CademPVD' Version 18.00 by CADEM Softwares , Pune , Website www.cadem.net

Licensee :

CADEM Softwares, 411003

Customer

ABC Company Ltd.

Project / Equipment

Soap Plant / PV-01 - Gas Filter

Designed By / Revision and Date

/ R00 , 24/Aug/2018 11:17:33

Index

Sr. No.	Description	Page No
1	Title page & equipment info	
2	Design data	
3	Material of constructions	
4	Effective Pressures	
5	Weight summary report	
6	Wind load calculations	
7	Seismic load calculations	
8	Design of Bolted Cover (Front)	
9	Design of Bolted Cover (Front)	
10	Design of Shell Flng (Front)	
11	Design of Shell Flng (Front)	
12	Design of Main Shell	
13	Design of Dished End (Rear)	
14	Design of Lug Support	
15	Design of Lug Support	
16	Design of N 01	
17	Design of N 02	
18	Design of N 03	
19	Design of Lifting Lugs	
20	Foundation load data	
21	C.G. Data	

'CadempVD' Version 18.00 by CADEM Softwares , Pune , Website www.cadem.net

Customer ABC Company Ltd.
Project Soap Plant
Location Vapi Site
Plant Refrigeration Plant

EQUIPMENT INFORMATION :

Design Code ASME VIII Div.1, 15
Equipment Name PV-01 - Gas Filter
Equipment Type Pressure Vessel
Equipment Class N.A.
Equipment Category N.A.
Reference Drawing No ---
Service Other Service
Support Type Lug Supports

DESIGN & REVIEWAL :

Designed By
Design Date 24/Aug/2018 11:17:33
Checked By
Approved By
Revision R00

INSPECTION & APPROVAL :

Inspection Agency ---
Reviewed By ---

EQUIPMENT DATA :

Front end Flat End
Front end flanged True
Rear end Dished End
Rear end flanged False
Shell ID 1250 mm
Shell OD 1274 mm
Length, Shell (W.L. to W.L.) / Overall 1650 / 2122.8 mm

OTHER DATA :

Fabricated weight (corr / uncorr) 2415.5 / 2660.6 kgf
Empty weight + external weights (corr / uncorr) 2415.5 / 2660.6 kgf
Estimated operating weight (corr / uncorr) 4789.1 / 5009.7 kgf
Estimated hydrotest weight (corr / uncorr) 4701.6 / 4922.3 kgf

'CadempVD' Version 18.00 by CADEM Softwares , Pune , Website www.cadem.net

Licensee :

CADEM Softwares, 411003

Customer

ABC Company Ltd.

Project / Equipment

Soap Plant / PV-01 - Gas Filter

Designed By / Revision and Date

/ R00 , 24/Aug/2018 11:17:33

VESSEL DESIGN DATA

(1) PROCESS DETAILS :

	MEDIA	DENSITY kg/m ³
Operating	Process	1000
Design1		1000
Design2		
Startup		
Shutdown		
Upset		
Hydrotest	Water	1000
Pneumatic	Air	1.2

(2) PR. : kgf/mm² g

	INT.	EXT.
Operating	0.12	0.01055
Design1	0.15	0.01055
Design2		
Startup		
Shutdown		
Upset		

(3) TEST PR. : kgf/mm² g

	Input Pr	MAWP	MAP
Hydrotest	0.195	0.195	0.195
Pneumatic	0.165	0.165	0.165

(4) TEMPERATURE : °C

	Input	MIN. MDMT	MAX.
Operating	25	25	120
Design1	15	15	150
Design2			
Startup			
Shutdown			
Upset			
Hydrotest	21.67	21.67	45
Pneumatic	21.67	10	45

(5) ALLOWANCES : mm

	INT.	EXT.
Corrosion	3	0
Polishing	0	0

(6) RADIOGRAPHY & JOINT EFFICIENCY :

	RADIOGRAPHY	JOINT EFFICIENCY
Shell	Spot	0.85
Head	Full	1.00

'CademPVD' Version 18.00 by CADEM Softwares , Pune , Website www.cadem.net

Licensee :

CADEM Softwares, 411003

Customer

ABC Company Ltd.

Project / Equipment

Soap Plant / PV-01 - Gas Filter

Designed By / Revision and Date

/ R00 , 24/Aug/2018 11:17:33

VESSEL DESIGN DATA

1. MATERIAL OF CONSTRUCTION :

	Shell side
Shell	SA-516 GR. 70 Plt. [UNS:K02700]
Head	SA-516 GR. 70 Plt. [UNS:K02700]
Body flange	SA-105 Frg. [UNS:K03504]
Body flange cover	SA-105 Frg. [UNS:K03504]
Liner	

2. NOZZLE CONNECTIONS :

	Shell side
Nozzle neck <= NPS 40	SA-106 GR. B Smls. Pipe [UNS:K03006]
Flange	SA-105 Frg. [UNS:K03504]
Cover flange	SA-105 Frg. [UNS:K03504]
Nozzle NPS > 40 & < 200	SA-106 GR. B Smls. Pipe [UNS:K03006]
Flange	SA-105 Frg. [UNS:K03504]
Cover flange	SA-105 Frg. [UNS:K03504]
Nozzle neck >= NPS 200	SA-516 GR. 70 Plt. [UNS:K02700]
Flange	SA-516 GR. 70 Plt. [UNS:K02700]
Cover flange	SA-516 GR. 70 Plt. [UNS:K02700]
Pad flange	SA-516 GR. 70 Plt. [UNS:K02700]
Pad flange cover	SA-516 GR. 70 Plt. [UNS:K02700]
Manhole flange	SA-516 GR. 70 Plt. [UNS:K02700]
Manhole cover	SA-516 GR. 70 Plt. [UNS:K02700]
Reinforcement pad	SA-516 GR. 70 Plt. [UNS:K02700]
External bolt	SA-193 GR. B7 Bolt [UNS:G41400]
External gasket	CAF with suitable binder (3 mm.)
Stiffener	SA-516 GR. 70 Plt. [UNS:K02700]
Lifting lug	IS-2062 GR. A Plt.
Support	IS-2062 GR. A Plt.
Anchor bolt	Commercial CS Bolt

3. INSULATION & CLADDING:

Mat. / Density / Thk.	Rockwool (Mineral Fibre) / 136.2 kg/m ³ / 40 mm
Mat. / Thk.	Al. sheet / 1.191 mm

'CademPVD' Version 18.00 by CADEM Softwares , Pune , Website www.cadem.net

Licensee : CADEM Softwares, 411003

Customer ABC Company Ltd.

Project / Equipment Soap Plant / PV-01 - Gas Filter

Designed By / Revision and Date / R00 , 24/Aug/2018 11:17:33

SUMMARY OF EFFECTIVE DESIGN PRESSURES IN kgf/mm² g VS TEMPERATURE IN °C

Sr. No.	Item name	Temp.	Inside pr.		Liquid pr.	Effective pr.	
			+ve	-ve		+ve	-ve
1	Bolted Cover (Front)	120	0.12	0.01055	0	0.12	0.01055
2	Shell Flng (Front)	120	0.12	0.01055	0	0.12	0.01055
3	Main Shell	120	0.12	0.01055	0	0.12	0.01055
4	Dished End (Rear)	120	0.12	0.01055	0	0.12	0.01055
5							

'CadempVD' Version 18.00 by CADEM Softwares , Pune , Website www.cadem.net

Licensee :

CADEM Softwares, 411003

Customer

ABC Company Ltd.

Project / Equipment

Soap Plant / PV-01 - Gas Filter

Designed By / Revision and Date

/ R00 , 24/Aug/2018 11:17:33

ITEM WISE WEIGHT SUMMARY

Sr.No.	Item name	Item size	Empty wt kgf	Volume m ³	Filled wt kgf
1	Bolted Cover (Front)	Blind Cover - 1463 OD x 84.304 Thk, RF, 1413 PCD, Tgrv = 1.588	1100.8	0	1100.8
2	Shell Flng (Front)	Plate Ring - 1463 OD x 1250 ID x 1413 PCD, RF, 119.522 Thk, Trgv = 1.588	423.7	0	423.7
3	Gasket Flng (Front)	1381.943 OD x 1250 ID, 3.175 Thk	0.1	0	0.1
4	Bolt Flng (Front)	Hex Head Bolt M22 x 240.751 Lg, 56 Nos.	40.57	0	40.57
5	Main Shell	1274 OD x 12 Thk, 1650 Lg	621.4	2.025	2646.3
6	Dished End (Rear)	Elliptical D/2H = 2.0, 1274 OD x 12 Nom / 10.8 Min Thk, SF = 50	203.2	0.317	520.3
7	Bolting Plate	222 Long x 200 Wide x 16 Thk, 4 Nos.	22.5	0	22.5
8	Gusset Plate	200 Long x 190 Wide x 16 Thk, 8 Nos.	38.51	0	38.51
9	Anchor Bolt	Anchor M20 x 200 Lg, 4 Nos.	1.99	0	1.99
10	Support Pad	275 Long x 272 Wide x 12 Thk, 4 Nos.	28.42	0	28.42
11	N 01	ANSIB36.10, 150 NPS Sch.80, 156 Lg	6.697	0.00262	9.32
12	Flange [N 01]	Weld Neck, ANSI B16.5, RF, 150# for 150 NPS Sch 80 Pipe	8.08	0	8.08
13	Gasket [N 01]	150 NPS x 150#, 3.175 Thk	0.1	0	0.1
14	Counter Flng [N 01]	Weld Neck, ANSI B16.5, RF, 150# for 150 NPS Sch 80 Pipe	8.08	0	8.08
15	Reinf [N 01]	292.659 OD x 171.275 ID x 12 Thk	4.202	0	4.202
16	N 02	ANSIB36.10, 150 NPS Sch.80, 156 Lg	6.697	0.00262	9.32
17	Flange [N 02]	Weld Neck, ANSI B16.5, RF, 150# for 150 NPS Sch 80 Pipe	8.08	0	8.08
18	Gasket [N 02]	150 NPS x 150#, 3.175 Thk	0.1	0	0.1
19	Counter Flng [N 02]	Weld Neck, ANSI B16.5, RF, 150# for 150 NPS Sch 80 Pipe	8.08	0	8.08
20	Reinf [N 02]	292.659 OD x 171.275 ID x 12 Thk	4.202	0	4.202
21	N 03	ANSIB36.10, 150 NPS Sch.160, 151 Lg	10.29	0.00206	12.35
22	Flange [N 03]	Weld Neck, ANSI B16.5, RF, 150# for 150 NPS Sch 160 Pipe	9.203	0	9.203

23	Gasket [N 03]	150 NPS x 150#, 3.175 Thk	0.1	0	0.1
24	Bolted Cover [N 03]	Blind Cover, ANSI B16.5, RF, 150# for 150 NPS Pipe	11.56	0	11.56
25	Reinf [N 03]	263.5 OD x 171.275 ID x 12 Thk	2.992	0	2.992
26	Lifting Lugs	120 Long x 70 Wide x 14 Thk, 2 Nos.	1.862	0	1.862
27	Pad (Lifting Lugs)	70 Long x 170 Wide x 8 Thk, 2 Nos.	1.507	0	1.507
28	Insulation	4178.318 W x 3622.804 L, 40 Thk	82.44	0	82.44
29	Cladding	4182.059 W x 3622.804 L, 1.191 Thk	4.993	0	4.993
30					
31					
32					
33					
34					
35					
			Σ 2660.6		Σ 4922.3

'CademPVD' Version 18.00 by CADEM Softwares , Pune , Website www.cadem.net

Licensee : CADEM Softwares, 411003
Customer ABC Company Ltd.
Project / Equipment Soap Plant / PV-01 - Gas Filter
Designed By / Revision and Date / R00 , 24/Aug/2018 11:17:33

WIND LOAD CALCULATION

CODE

Wind [IS:875, 87]

1. DESIGN CONDITIONS (Operating Mode , Corroded Condition) :

Basic wind speed	(Section 5.2)	Vb	50 m/s
Expected life of equipment	(Section 5.3.1)		25 Years
Probability factor (Risk coeff)	(Section 5.3.1)	K1	0.902
Terrain category	(Section 5.3.2)		Category 2
Structure class	(Section 5.3.2.2)		Class B
Topography factor	(Section 5.3.3)	K3	1.3
Force coefficient (Shape factor)		Cf	0.8

3. CALCULATION OF FORCES AND MOMENTS:

Equivalent diameter		De	1862 mm
Overall length of equipment		L	2122.8 mm
Height of C.G. of equipment		Hcg	1738.9 mm
Size and height factor	(Section 5.3.2)	K2	0.98
Effective transverse cross sectional area			
= De x L		A	3952660.7 mm ²
Effective wind speed			
= K1 x K2 x K3 x Vb		Vz	57.44 m/s
Wind pressure			
= 6E-08 x Vz ²		Pz	0.0002 kgf/mm ²
Longitudinal force			
= Cf x A x Pz		F	626.1 kgf
Support elevation		H	474.5 mm
Turning moment			
= F x (Hcg - H)		M	791596.4 kgf-mm

'CadempVD' Version 18.00 by CADEM Softwares , Pune , Website www.cadem.net

Licensee :

CADEM Softwares, 411003

Customer

ABC Company Ltd.

Project / Equipment

Soap Plant / PV-01 - Gas Filter

Designed By / Revision and Date

/ R00 , 24/Aug/2018 11:17:33

SEISMIC LOAD CALCULATION

CODE

Seismic [IS:1893, 02]

1. DESIGN CONDITIONS (Operating Mode , Corroded Condition) :

Weight of equipment		Wo	4789.1 kgf
Importance factor	(Table-6 , 2002)	I	1.5
Soil profile type			Stiff Soil Profile (SD)
Foundation type			RCC footings + Tie Beams
Damping factor			5
Seismic zone			Zone III
Seismic zone factor	(Table-2 , 2002)	Z	0.16
Response reduction factor	(Table-7 , 2002)	R	2.9
Spectral accelerations coeff.	(Fig. 2 , 2002)	Sa / g	2.5, Use max value
Damping correction factor	(Table-3 , 2002)	Cf	1
Seismic coefficient	(Clause-6.4.2 , 2002)		
	$= 0.5 \times Z \times I \times Cf \times (Sa / g) \times (1 / R)$		
	$= 0.5 \times 0.16 \times 1.5 \times 1 \times$		
	$2.5 \times (1 / 2.9)$	Ah	0.103

2. CALCULATION OF FORCES AND MOMENTS:

Elevation of support		H	474.5 mm
Height of C.G. of equipment		Hcg	1381.1 mm
Seismic base shear force			
	$= Ah \times Wo$		
	$= 0.103 \times 4789.1$	Vb	433.7 kgf
Seismic moment of support			
	$= Vb \times (Hcg - H)$		
	$= 433.7 \times (1381.1 - 474.5)$	M	393227.8 kgf-mm

'CadempVD' Version 18.00 by CADEM Softwares , Pune , Website www.cadem.net

Licensee : CADEM Softwares, 411003
Customer ABC Company Ltd.
Project / Equipment Soap Plant / PV-01 - Gas Filter
Designed By / Revision and Date / R00 , 24/Aug/2018 11:17:33

DESIGN OF FLAT BOLTED HEAD (INTERNAL)

CODE

Bolted Cover (Front)

ASME VIII Div.1, 15

1. DESIGN CONDITIONS (Operating Mode , Corroded Condition) :

Design pressure	P	0.12 kgf/mm ² g
Design temperature	T	120 °C
Allowance	CA	3 mm
Groove allowance	Tg	0 mm
Radiography		Full
Joint efficiency	E	1

2. COVER DATA :

M.O.C.		SA-105 Frg. [UNS:K03504]
Code allw. stress @ design temp.	Sfo	14.06 kgf/mm ²
Code allw. stress @ atm. temp.	Sfa	14.06 kgf/mm ²
Young's modulus	Ey	20079.7 kgf/mm ²
Self reinforced		False
Flange OD	A	1463 mm
Thickness provided		84.3 mm
Thickness available		81.3 mm

3. BOLTING DATA :

M.O.C.		SA-193 GR. B7 Bolt [UNS:G41400]
Code allw. stress @ design temp.	Sb	17.58 kgf/mm ²
Code allw. stress @ atm. temp.	Sa	17.58 kgf/mm ²
Bolt PCD	PCD	1413 mm
Bolt dia.	db	22 mm
No. of bolts	nb	56

4. LINER DATA :

M.O.C.		
Liner ID		mm
Liner OD		mm
Liner thk.		mm

5. GASKET DATA :

M.O.C.		CAF with suitable binder (3 mm.)
Gasket seating stress	y	1.125 kgf/mm ²
Gasket factor	m	2
Inside diameter	Gi	1256 mm
Outside diameter	Go	1381.9 mm
Width of gasket	N	62.97 mm
Width of gasket (as per Table 2-5.2)		31.75 mm
Basic gasket seating width (as per Table 2-5.2)	b0	31.49 mm
Effective gasket width (as per Table 2-5.2)	b	14.14 mm
Dia. at load reaction (see Table 2-5.2)	G	1353.7 mm
Pass partition gasket width	Wp	0 mm
Pass partition gasket length	Lp	0 mm
Effective pass partition gasket width	b'	0 mm

6. BOLT LOAD CALCULATIONS AS PER APPENDIX 2-5 (b1) :

Total joint - contact surface compression load [Hp]

$$= 2 \times (\pi \times b \times G + b' \times Lp) \times m \times P$$

$$= 2 \times (\pi \times 14.14 \times 1353.7 + 0 \times 0) \times 2 \times 0.12$$

$$= 28863.3 \text{ kgf}$$

Total hydrostatic end force [H]

$$= 0.25 \times \pi \times G^2 \times P$$

$$= 0.25 \times \pi \times 1353.7^2 \times 0.12$$

$$= 172700.1 \text{ kgf}$$

Minimum required bolt load for operating condition [Wm1]

$$= Hp + H$$

$$= 28863.3 + 172700.1$$

$$= 201563.5 \text{ kgf}$$

7. BOLT LOAD CALCULATIONS AS PER APPENDIX 2-5 (b2) :

Minimum required bolt load for gasket seating [Wm2]

$$= (\pi \times b \times G + b' \times Lp) \times y$$

$$= (\pi \times 14.14 \times 1353.7 + 0 \times 0) \times 1.125$$

$$= 67643.1 \text{ kgf}$$

8. BOLT AREAS AS PER APPENDIX 2-5 (d) :

Total required cross-sectional area of bolts [Am]

$$= \text{MAX} [Wm2 / Sa , Wm1 / Sb] \dots\dots\dots \text{For Internal '+' Pr Design}$$

$$= Wm2 / Sa \dots\dots\dots \text{For External Pr \& Self Sealing Design}$$

$$= 11467.6 \text{ mm}^2$$

Actual bolt area using root diameter [Ab]

$$= 15255.5 \text{ mm}^2$$

Flange design bolt load for the gasket seating [W]

$$= 0.5 \times (Am + Ab) \times Sa \times 1 \dots\dots\dots \text{average bolt area}$$

$$= Ab \times Sa \times 1 \dots\dots\dots \text{full bolt area}$$

$$= 234852.5 \text{ kgf (Avg. bolt area and margin factor of 1)}$$

9. CHECK FOR GASKET CRUSHING :

Minimum gasket width required [Nmin]

$$= Ab \times Sb / (2 \times \pi \times y \times G)$$

$$= 15255.5 \times 17.58 / (2 \times \pi \times 1.125 \times 1353.7)$$

$$= 28.03 \text{ mm}$$

10. DESIGN CALCULATION AS PER UG 34

Self reinforced		False
Factor C is user input		False
Factor C taken from fig. UG 34 or user input	C	0.3
Factor, 2 ^{0.5} for self reinf. cover, otherwise 1	F	1

Required thickness for bolting condition [t]

$$= G \times F \times \text{SQRT} [1.9 \times W \times 0.5 \times (PCD - G) / (Sfa \times E \times G^3)]$$

$$= 1353.7 \times 1 \times \text{SQRT} [1.9 \times 234852.5 \times 0.5 \times (1413 - 1353.7) / (14.06 \times 1 \times 1353.7^3)]$$

$$= 26.37 \text{ mm}$$

Required thickness for operating condition [t]

$$= G \times F \times \text{SQRT} \{ [C \times P / (Sfo \times E)] + 1.9 \times Wm1 \times 0.5 \times (PCD - G) / (Sfo \times E \times G^3) \}$$

$$= 1353.7 \times 1 \times \text{SQRT} \{ [0.3 \times 0.12 / (14.06 \times 1)] + 1.9 \times 201563.5 \times 0.5 \times (1413 - 1353.7) / (14.06 \times 1 \times 1353.7^3) \}$$

$$= 72.72 \text{ mm}$$

'CadempVD' Version 18.00 by CADEM Softwares , Pune , Website www.cadem.net

Licensee : CADEM Softwares, 411003
Customer ABC Company Ltd.
Project / Equipment Soap Plant / PV-01 - Gas Filter
Designed By / Revision and Date / R00 , 24/Aug/2018 11:17:33

DESIGN OF FLAT BOLTED HEAD (EXTERNAL)

CODE

Bolted Cover (Front)

ASME VIII Div.1, 15

1. DESIGN CONDITIONS (Operating Mode , Corroded Condition) :

Design pressure	P	0.01055 kgf/mm ² g
Design temperature	T	120 °C
Allowance	CA	3 mm
Groove allowance	Tg	0 mm
Radiography		Full
Joint efficiency	E	1

2. COVER DATA :

M.O.C.		SA-105 Frg. [UNS:K03504]
Code allw. stress @ design temp.	Sfo	14.06 kgf/mm ²
Code allw. stress @ atm. temp.	Sfa	14.06 kgf/mm ²
Young's modulus	Ey	20079.7 kgf/mm ²
Self reinforced		False
Flange OD	A	1463 mm
Thickness provided		84.3 mm
Thickness available		81.3 mm

3. BOLTING DATA :

M.O.C.		SA-193 GR. B7 Bolt [UNS:G41400]
Code allw. stress @ design temp.	Sb	17.58 kgf/mm ²
Code allw. stress @ atm. temp.	Sa	17.58 kgf/mm ²
Bolt PCD	PCD	1413 mm
Bolt dia.	db	22 mm
No. of bolts	nb	56

4. LINER DATA :

M.O.C.		
Liner ID		mm
Liner OD		mm
Liner thk.		mm

5. GASKET DATA :

M.O.C.		CAF with suitable binder (3 mm.)
Gasket seating stress	y	1.125 kgf/mm ²
Gasket factor	m	2
Inside diameter	Gi	1256 mm
Outside diameter	Go	1381.9 mm
Width of gasket	N	62.97 mm
Width of gasket (as per Table 2-5.2)		31.75 mm
Basic gasket seating width (as per Table 2-5.2)	b0	31.49 mm
Effective gasket width (as per Table 2-5.2)	b	14.14 mm
Dia. at load reaction (see Table 2-5.2)	G	1353.7 mm
Pass partition gasket width	Wp	0 mm
Pass partition gasket length	Lp	0 mm
Effective pass partition gasket width	b'	0 mm

6. BOLT LOAD CALCULATIONS AS PER APPENDIX 2-5 (b1) :

Total joint - contact surface compression load [Hp]
 = $2 \times (\pi \times b \times G + b' \times Lp) \times m \times P$
 = $2 \times (\pi \times 14.14 \times 1353.7 + 0 \times 0) \times 2 \times 0.01055$
 = 2536.6 kgf

Total hydrostatic end force [H]
 = $0.25 \times \pi \times G^2 \times P$
 = $0.25 \times \pi \times 1353.7^2 \times 0.01055$
 = 15177.5 kgf

Minimum required bolt load for operating condition [Wm1]
 = Hp + H
 = 2536.6 + 15177.5
 = 17714.1 kgf

7. BOLT LOAD CALCULATIONS AS PER APPENDIX 2-5 (b2) :

Minimum required bolt load for gasket seating [Wm2]
 = $(\pi \times b \times G + b' \times Lp) \times y$
 = $(\pi \times 14.14 \times 1353.7 + 0 \times 0) \times 1.125$
 = 67643.1 kgf

8. BOLT AREAS AS PER APPENDIX 2-5 (d) :

Total required cross-sectional area of bolts [Am]
 = MAX [Wm2 / Sa , Wm1 / Sb] For Internal '+' Pr Design
 = Wm2 / Sa For External Pr & Self Sealing Design
 = 3848.4 mm²

Actual bolt area using root diameter [Ab]
 = 15255.5 mm²

Flange design bolt load for the gasket seating [W]
 = $0.5 \times (Am + Ab) \times Sa \times 1$ average bolt area
 = $Ab \times Sa \times 1$ full bolt area
 = 167892.3 kgf (Avg. bolt area and margin factor of 1)

9. CHECK FOR GASKET CRUSHING :

Minimum gasket width required [Nmin]
 = $Ab \times Sb / (2 \times \pi \times y \times G)$
 = $15255.5 \times 17.58 / (2 \times \pi \times 1.125 \times 1353.7)$
 = 28.03 mm

10. DESIGN CALCULATION AS PER UG 34

Self reinforced		False
Factor C is user input		False
Factor C taken from fig. UG 34 or user input	C	0.3
Factor, $2^{0.5}$ for self reinf. cover, otherwise 1	F	1

Required thickness for bolting condition [t]
 = $G \times F \times \text{SQRT} [1.9 \times W \times 0.5 \times (PCD - G) / (Sfa \times E \times G^3)]$
 = $1353.7 \times 1 \times \text{SQRT} [1.9 \times 167892.3 \times 0.5 \times (1413 - 1353.7) / (14.06 \times 1 \times 1353.7^3)]$
 = 26.37 mm

Required thickness for operating condition [t]
 = $G \times F \times \text{SQRT} \{ [C \times P / (Sfo \times E)] + 1.9 \times Wm1 \times 0.5 \times (PCD - G) / (Sfo \times E \times G^3) \}$
 = $1353.7 \times 1 \times \text{SQRT} \{ [0.3 \times 0.01055 / (14.06 \times 1)] + 1.9 \times 17714.1 \times 0.5 \times (1413 - 1353.7) / (14.06 \times 1 \times 1353.7^3) \}$
 = 31.77 mm

'CadempVD' Version 18.00 by CADEM Softwares , Pune , Website www.cadem.net

Licensee : CADEM Softwares, 411003
Customer ABC Company Ltd.
Project / Equipment Soap Plant / PV-01 - Gas Filter
Designed By / Revision and Date / R00 , 24/Aug/2018 11:17:33

FLANGE DESIGN (INTERNAL)

CODE

Shell Flng (Front)

ASME VIII Div.1, 15

1. DESIGN CONDITIONS (Operating Mode , Corroded Condition) :

Design pressure	P	0.12 kgf/mm ² g
Design temperature	T	120 °C
Allowance	CA	3 mm
Groove allowance	Tg	0 mm

2. FLANGE DATA :

M.O.C.		SA-105 Frg. [UNS:K03504]
Code allw. stress @ design temp.	Sfo	14.06 kgf/mm ²
Code allw. stress @ atm. temp.	Sfa	14.06 kgf/mm ²
Inside diameter	B	1256 mm
Outside diameter	A	1463 mm
Hub length	h	12 mm
Thickness (hub end)	g1	21 mm
Thickness (pipe end)	g0	9 mm
Thickness provided		119.5 mm
Thickness available		116.5 mm

3. BOLTING DATA :

M.O.C.		SA-193 GR. B7 Bolt [UNS:G41400]
Code allw. stress @ design temp.	Sb	17.58 kgf/mm ²
Code allw. stress @ atm. temp.	Sa	17.58 kgf/mm ²
Bolt PCD	C	1413 mm
Bolt dia.	db	22 mm
No. of bolts	nb	56

4. LINER DATA :

M.O.C.		
Liner ID		mm
Liner OD		mm
Liner thk.		mm

5. GASKET DATA :

5a. Flange gasket data :

M.O.C.		CAF with suitable binder (3 mm.)
Gasket type		Ring Gasket
Gasket confinement type		Unconfined
Flange face type		Raised Face
Flange gasket surface finish		Serrated (Normal)
Counter flange face type		Raised Face
Counter gasket surface finish		Serrated (Normal)
Applicable gasket sketch in Table 2-5.2		Type 1B
Applicable gasket column in Table 2-5.2		1
Gasket seating stress (refer to Note 1, Table 2-5.1)	y	1.125 kgf/mm ²
Gasket factor (from Table 2-5.1)	m	2
Inside diameter	Gi	1256 mm
Outside diameter	Go	1381.9 mm
Width of gasket (as per Table 2-5.2)	N	62.97 mm

Width of gasket	(as per Table 2-5.2)	w	62.97 mm
Width of raised face or gasket contact width	(as per Table 2-5.2)		31.75 mm
Basic gasket seating width	(as per Table 2-5.2)	b0	31.49 mm
Effective gasket width	(as per Table 2-5.2)	b	14.14 mm
Dia. at load reaction	(see Table 2-5.2)	G	1353.7 mm

5b. Partition groove gasket data (For H.E. body flange) :

M.O.C.		--	
Gasket seating stress	(refer to Note 1, Table 2-5.1)	y'	0 kgf/mm ²
Gasket factor	(from Table 2-5.1)	m'	0
Pass partition gasket width		Wp	0 mm
Pass partition gasket length		Lp	0 mm
Effective pass partition gasket width		b'	0 mm

6. BOLT LOAD CALCULATIONS AS PER APPENDIX 2-5 (b1)

Total joint - contact surface compression load [Hp]
 $= 2 \times (\pi \times b \times G \times m + b' \times Lp \times m') \times P$
 $= 2 \times (\pi \times 14.14 \times 1353.7 \times 2 + 0 \times 0 \times 0) \times 0.12$
 $= 28863.3 \text{ kgf}$
Total hydrostatic end force [H]
 $= 0.25 \times \pi \times G^2 \times P$
 $= 0.25 \times \pi \times 1353.7^2 \times 0.12$
 $= 172700.1 \text{ kgf}$
Minimum required bolt load for operating condition [Wm1a]
 $= Hp + H$
 $= 28863.3 + 172700.1$
 $= 201563.5 \text{ kgf}$
Minimum required bolt load for operating condition [Wm1b]
(from mating flange)
 $= 201563.5 \text{ kgf}$
Governing bolt load for operating condition [Wm1]
 $= \text{MAX} [Wm1a , Wm1b]$
 $= \text{MAX} [201563.5 , 201563.5]$
 $= 201563.5 \text{ kgf}$

7. BOLT LOAD CALCULATION AS PER APPENDIX 2-5 (b2)

Minimum required bolt load for gasket seating [Wm2]
 $= (\pi \times b \times G \times y + b' \times Lp \times y')$
 $= (\pi \times 14.14 \times 1353.7 \times 1.125 + 0 \times 0 \times 0)$
 $= 67643.1 \text{ kgf}$

8. BOLT AREAS AS PER APPENDIX 2-5 (d)

Total required cross-sectional area of bolts [Am]
 $= \text{MAX} [Wm2 / Sa , Wm1 / Sb]$ For Internal '+' Pr Design
 $= Wm2 / Sa$ For External Pr & Self Sealing Design
 $= 11467.6 \text{ mm}^2$
Actual bolt area using root diameter [Ab]
 $= 15255.5 \text{ mm}^2$
Flange design bolt load for the gasket seating [W]
 $= 0.5 \times (Am + Ab) \times Sa \times 1$ average bolt area
 $= Ab \times Sa \times 1$ full bolt area
 $= 234852.5 \text{ kgf}$ (Avg. bolt area and margin factor of 1)

9. CHECK FOR GASKET CRUSHING

Minimum gasket width required [Nmin]
 $= Ab \times Sb / (2 \times \pi \times y \times G)$
 $= 15255.5 \times 17.58 / (2 \times \pi \times 1.125 \times 1353.7)$
 $= 28.03 \text{ mm}$

10. BOLT SPACING CORRECTION FACTOR

As per Brownell & Young or IS 2825,
 $= \text{SQRT} [\text{Bolt spacing} / (2 \times db + t)]$
As per TEMA or BS 5500,
 $= \text{SQRT} [\text{Bolt spacing} / Bmax]$ where,

$$B_{max} = \text{maximum recommended bolt spacing} = 2 \times db + 6 \times t / (m + 0.5)$$

Code Select, $C_f = 1$ (min. equal to 1)

INTEGRAL FLANGE DESIGN

Shell Flng (Front)

11. LOADS AND FORCES DURING OPERATING CONDITION AS PER APPENDIX 2-3

Hydrostatic end force on area inside of flange [HD]

$$\begin{aligned} &= 0.25 \times \pi \times B^2 \times P \\ &= 0.25 \times \pi \times 1256^2 \times 0.12 \\ &= 148679.3 \text{ kgf} \end{aligned}$$

Gasket load (difference between flange design bolt load and total hydrostatic end force) [HG]

$$\begin{aligned} &= W_{m1} - H \\ &= 201563.5 - 172700.1 \\ &= 28863.3 \text{ kgf} \end{aligned}$$

Difference between total hydrostatic end force and hydrostatic end force on area inside of flange [HT]

$$\begin{aligned} &= H - HD \\ &= 172700.1 - 148679.3 \\ &= 24020.9 \text{ kgf} \end{aligned}$$

12. MOMENT ARMS FOR FLANGE LOADS AS PER TABLE 2-6

Radial distance from the bolt circle to intersection of hub and back of flange, as per Appendix 2-3 [R]

$$\begin{aligned} &= 0.5 \times (C - B) - g_1 \\ &= 0.5 \times (1413 - 1256) - 21 \\ &= 57.5 \text{ mm} \end{aligned}$$

Radial distance from the bolt circle to the circle on which HD acts [hD]

$$\begin{aligned} &= R + 0.5 \times g_1 \\ &= 57.5 + 0.5 \times 21 \\ &= 68 \text{ mm} \end{aligned}$$

Radial distance from gasket load reaction to the bolt circle [hG]

$$\begin{aligned} &= 0.5 \times (C - G) \\ &= 0.5 \times (1413 - 1353.7) \\ &= 29.67 \text{ mm} \end{aligned}$$

Radial distance from the bolt circle to the circle on which HT acts [hT]

$$\begin{aligned} &= 0.5 \times (R + g_1 + hG) \\ &= 0.5 \times (57.5 + 21 + 29.67) \\ &= 54.08 \text{ mm} \end{aligned}$$

13. FLANGE MOMENTS UNDER OPERATING CONDITION AS PER APPENDIX 2-6

Component of moment due to HD [MD]

$$\begin{aligned} &= HD \times hD \\ &= 148679.3 \times 68 \\ &= 10110190 \text{ kgf-mm} \end{aligned}$$

Component of moment due to HG [MG]

$$\begin{aligned} &= HG \times hG \\ &= 28863.3 \times 29.67 \\ &= 856321.7 \text{ kgf-mm} \end{aligned}$$

Component of moment due to HT [MT]

$$\begin{aligned} &= HT \times hT \\ &= 24020.9 \times 54.08 \\ &= 1299146.8 \text{ kgf-mm} \end{aligned}$$

Total moment acting on the flange for operating condition [MO]

$$\begin{aligned} &= MD + MG + MT \\ &= 10110190 + 856321.7 + 1299146.8 \\ &= 12265658.5 \text{ kgf-mm} \end{aligned}$$

14. LOADS AND FORCES DURING GASKET SEATING AS PER APPENDIX 2-3

Gasket load for seating condition [HG]

$$\begin{aligned} &= W \\ &= 234852.5 \text{ kgf} \end{aligned}$$

15. MOMENT UNDER GASKET SEATING AS PER APPENDIX 2-6

Total moment acting on the flange for gasket seating [MO']

$$\begin{aligned} &= W \times hG \\ &= 234852.5 \times 29.67 \\ &= 6967639.1 \text{ kgf-mm} \end{aligned}$$

16. SHAPE CONSTANTS

A / B

K 1.165

Flange factors from Fig. 2-7.1

T	1.853
Z	6.606
Y	12.8
U	14.06
	106.3
e	0.00849
F	0.903
V	0.417
	2.333
	0.113
d	290617.3
f	4.354

h0

F / h0

Factor from Fig. 2-7.2

Factor from Fig. 2-7.3

g1 / g0

h / h0

(U / V) x h0 x g0²

Factor from Fig. 2-7.6

17. STRESS FORMULA FACTORS

Assumed thickness [t]

= 106.2 mm

Factor [α]

= t x e + 1

= 106.2 x 0.00849 + 1

= 1.902

Factor [β]

= 1.333 x t x e + 1

= 1.333 x 106.2 x 0.00849 + 1

= 2.202

Factor [γ]

= α / T

= 1.902 / 1.853

= 1.026

Factor [δ]

= t³ / d

= 106.2³ / 290617.3

= 4.12

Factor [λ]

= γ + δ

= 1.026 + 4.12

= 5.147

18. FLANGE STRESSES AS PER APPENDIX 2-7 & 2-8

Equivalent moment [Mmax]

= MAX [MO , MO' x Sfo / Sfa]

= MAX [12265658.5 , 6967639.1 x 14.06 / 14.06]

= 12265658.5 kgf-mm

Corrected equivalent moment per unit length [M]

= Mmax x (Cf / B)

= 12265658.5 x (1 / 1256)

= 9765.7 kgf

Longitudinal hub stress [SH]

= f x M / (λ x g1²)

= 4.354 x 9765.7 / (5.147 x 21²)

= 18.73 kgf/mm² < 1.5 x Sfo

Radial flange stress [SR]

= β x M / (λ x t²)

= 2.202 x 9765.7 / (5.147 x 106.2²)

= 0.371 kgf/mm² < Sfo

Tangential flange stress [ST]

= (M x Y / t²) - Z x SR

= (9765.7 x 12.8 / 106.2²) - 6.606 x 0.371

= 8.633 kgf/mm² < Sfo

Average stress

$$= \text{MAX} [0.5 \times (SH + SR) , 0.5 \times (SH + ST)]$$

$$= \text{MAX} [0.5 \times (18.73 + 0.371) , 0.5 \times (18.73 + 8.633)]$$

$$= 13.68 \text{ kgf/mm}^2 \dots\dots\dots < Sfo$$

19. FLANGE RIGIDITY CHECKING AS PER APPENDIX 2-14

Modulus of elasticity for flange	Efo	20079.7 kgf/mm ²
Rigidity factor	KI	0.3

Rigidity index [J]

$$= 52.14 \times V \times M_{\text{max}} / (\lambda \times Efo \times g_0^2 \times KI \times h_0)$$

$$= 52.14 \times 0.417 \times 12265658.5 / (5.147 \times 20079.7 \times 9^2 \times 0.3 \times 106.3)$$

$$= 0.998$$

Since J < 1.0, design is safe

'CadempVD' Version 18.00 by CADEM Softwares , Pune , Website www.cadem.net

Licensee : CADEM Softwares, 411003
Customer ABC Company Ltd.
Project / Equipment Soap Plant / PV-01 - Gas Filter
Designed By / Revision and Date / R00 , 24/Aug/2018 11:17:33

FLANGE DESIGN (EXTERNAL)

CODE

Shell Flng (Front)

ASME VIII Div.1, 15

1. DESIGN CONDITIONS (Operating Mode , Corroded Condition) :

Design pressure	P	0.01055 kgf/mm ² g
Design temperature	T	120 °C
Allowance	CA	3 mm
Groove allowance	Tg	0 mm

2. FLANGE DATA :

M.O.C.		SA-105 Frg. [UNS:K03504]
Code allw. stress @ design temp.	Sfo	14.06 kgf/mm ²
Code allw. stress @ atm. temp.	Sfa	14.06 kgf/mm ²
Inside diameter	B	1256 mm
Outside diameter	A	1463 mm
Hub length	h	12 mm
Thickness (hub end)	g1	21 mm
Thickness (pipe end)	g0	9 mm
Thickness provided		119.5 mm
Thickness available		116.5 mm

3. BOLTING DATA :

M.O.C.		SA-193 GR. B7 Bolt [UNS:G41400]
Code allw. stress @ design temp.	Sb	17.58 kgf/mm ²
Code allw. stress @ atm. temp.	Sa	17.58 kgf/mm ²
Bolt PCD	C	1413 mm
Bolt dia.	db	22 mm
No. of bolts	nb	56

4. LINER DATA :

M.O.C.		
Liner ID		mm
Liner OD		mm
Liner thk.		mm

5. GASKET DATA :

5a. Flange gasket data :

M.O.C.		CAF with suitable binder (3 mm.)
Gasket type		Ring Gasket
Gasket confinement type		Unconfined
Flange face type		Raised Face
Flange gasket surface finish		Serrated (Normal)
Counter flange face type		Raised Face
Counter gasket surface finish		Serrated (Normal)
Applicable gasket sketch in Table 2-5.2		Type 1B
Applicable gasket column in Table 2-5.2		1
Gasket seating stress (refer to Note 1, Table 2-5.1)	y	1.125 kgf/mm ²
Gasket factor (from Table 2-5.1)	m	2
Inside diameter	Gi	1256 mm
Outside diameter	Go	1381.9 mm
Width of gasket (as per Table 2-5.2)	N	62.97 mm

Width of gasket	(as per Table 2-5.2)	w	62.97 mm
Width of raised face or gasket contact width	(as per Table 2-5.2)		31.75 mm
Basic gasket seating width	(as per Table 2-5.2)	b0	31.49 mm
Effective gasket width	(as per Table 2-5.2)	b	14.14 mm
Dia. at load reaction	(see Table 2-5.2)	G	1353.7 mm

5b. Partition groove gasket data (For H.E. body flange) :

M.O.C.			--
Gasket seating stress	(refer to Note 1, Table 2-5.1)	y'	0 kgf/mm ²
Gasket factor	(from Table 2-5.1)	m'	0
Pass partition gasket width		Wp	0 mm
Pass partition gasket length		Lp	0 mm
Effective pass partition gasket width		b'	0 mm

6. BOLT LOAD CALCULATIONS AS PER APPENDIX 2-5 (b1)

Total joint - contact surface compression load [Hp]
 $= 2 \times (\pi \times b \times G \times m + b' \times Lp \times m') \times P$
 $= 2 \times (\pi \times 14.14 \times 1353.7 \times 2 + 0 \times 0 \times 0) \times 0.01055$
 $= 2536.6 \text{ kgf}$
Total hydrostatic end force [H]
 $= 0.25 \times \pi \times G^2 \times P$
 $= 0.25 \times \pi \times 1353.7^2 \times 0.01055$
 $= 15177.5 \text{ kgf}$
Minimum required bolt load for operating condition [Wm1a]
 $= Hp + H$
 $= 2536.6 + 15177.5$
 $= 17714.1 \text{ kgf}$
Minimum required bolt load for operating condition [Wm1b]
(from mating flange)
 $= 17714.1 \text{ kgf}$
Governing bolt load for operating condition [Wm1]
 $= \text{MAX} [Wm1a , Wm1b]$
 $= \text{MAX} [17714.1 , 17714.1]$
 $= 17714.1 \text{ kgf}$

7. BOLT LOAD CALCULATION AS PER APPENDIX 2-5 (b2)

Minimum required bolt load for gasket seating [Wm2]
 $= (\pi \times b \times G \times y + b' \times Lp \times y')$
 $= (\pi \times 14.14 \times 1353.7 \times 1.125 + 0 \times 0 \times 0)$
 $= 67643.1 \text{ kgf}$

8. BOLT AREAS AS PER APPENDIX 2-5 (d)

Total required cross-sectional area of bolts [Am]
 $= \text{MAX} [Wm2 / Sa , Wm1 / Sb]$ For Internal '+' Pr Design
 $= Wm2 / Sa$ For External Pr & Self Sealing Design
 $= 3848.4 \text{ mm}^2$
Actual bolt area using root diameter [Ab]
 $= 15255.5 \text{ mm}^2$
Flange design bolt load for the gasket seating [W]
 $= 0.5 \times (Am + Ab) \times Sa \times 1$ average bolt area
 $= Ab \times Sa \times 1$ full bolt area
 $= 167892.3 \text{ kgf}$ (Avg. bolt area and margin factor of 1)

9. CHECK FOR GASKET CRUSHING

Minimum gasket width required [Nmin]
 $= Ab \times Sb / (2 \times \pi \times y \times G)$
 $= 15255.5 \times 17.58 / (2 \times \pi \times 1.125 \times 1353.7)$
 $= 28.03 \text{ mm}$

10. BOLT SPACING CORRECTION FACTOR

As per Brownell & Young or IS 2825,
 $= \text{SQRT} [\text{Bolt spacing} / (2 \times db + t)]$
As per TEMA or BS 5500,
 $= \text{SQRT} [\text{Bolt spacing} / Bmax]$ where,

$$B_{max} = \text{maximum recommended bolt spacing} = 2 \times db + 6 \times t / (m + 0.5)$$

Code Select, $C_f = 1$ (min. equal to 1)

INTEGRAL FLANGE DESIGN

Shell Flng (Front)

11. LOADS AND FORCES DURING OPERATING CONDITION AS PER APPENDIX 2-3

Hydrostatic end force on area inside of flange [HD]

$$\begin{aligned} &= 0.25 \times \pi \times B^2 \times P \\ &= 0.25 \times \pi \times 1256^2 \times 0.01055 \\ &= 13066.4 \text{ kgf} \end{aligned}$$

Difference between total hydrostatic end force and hydrostatic end force on area inside of flange [HT]

$$\begin{aligned} &= H - HD \\ &= 15177.5 - 13066.4 \\ &= 2111 \text{ kgf} \end{aligned}$$

12. MOMENT ARMS FOR FLANGE LOADS AS PER APPENDIX TABLE 2-6

Radial distance from the bolt circle to intersection of hub and back of flange, as per Appendix 2-3 [R]

$$\begin{aligned} &= 0.5 \times (C - B) - g_1 \\ &= 0.5 \times (1413 - 1256) - 21 \\ &= 57.5 \text{ mm} \end{aligned}$$

Radial distance from the bolt circle to the circle on which HD acts [hD]

$$\begin{aligned} &= R + 0.5 \times g_1 \\ &= 57.5 + 0.5 \times 21 \\ &= 68 \text{ mm} \end{aligned}$$

Radial distance from gasket load reaction to the bolt circle [hG]

$$\begin{aligned} &= 0.5 \times (C - G) \\ &= 0.5 \times (1413 - 1353.7) \\ &= 29.67 \text{ mm} \end{aligned}$$

Radial distance from the bolt circle to the circle on which HT acts [hT]

$$\begin{aligned} &= 0.5 \times (R + g_1 + hG) \\ &= 0.5 \times (57.5 + 21 + 29.67) \\ &= 54.08 \text{ mm} \end{aligned}$$

13. FLANGE MOMENTS UNDER OPERATING CONDITION AS PER APPENDIX 2-6

Component of moment due to HD [MD]

$$\begin{aligned} &= HD \times (hD - hG) \\ &= 13066.4 \times (68 - 29.67) \\ &= 500860.4 \text{ kgf-mm} \end{aligned}$$

Component of moment due to HT [MT]

$$\begin{aligned} &= HT \times (hT - hG) \\ &= 2111 \times (54.08 - 29.67) \\ &= 51542.9 \text{ kgf-mm} \end{aligned}$$

Total moment acting on the flange for operating condition [MO]

$$\begin{aligned} &= MD + MT \\ &= 500860.4 + 51542.9 \\ &= 552403.2 \text{ kgf-mm} \end{aligned}$$

14. LOADS AND FORCES DURING GASKET SEATING AS PER APPENDIX 2-3

Gasket load for seating condition [HG]

$$\begin{aligned} &= W \\ &= 167892.3 \text{ kgf} \end{aligned}$$

15. MOMENT UNDER GASKET SEATING AS PER APPENDIX 2-6

Total moment acting on the flange for gasket seating [MO']

$$\begin{aligned} &= W \times hG \\ &= 167892.3 \times 29.67 \\ &= 4981054.6 \text{ kgf-mm} \end{aligned}$$

16. SHAPE CONSTANTS

A / B	K	1.165
Flange factors from Fig. 2-7.1	T	1.853
	Z	6.606
	Y	12.8
	U	14.06
h0		106.3
F / h0	e	0.00849

Factor from Fig. 2-7.2	F	0.903
Factor from Fig. 2-7.3	V	0.417
g1 / g0		2.333
h / h0		0.113
(U / V) x h0 x g0 ²	d	290617.3
Factor from Fig. 2-7.6	f	4.354

17. STRESS FORMULA FACTORS

Assumed thickness [t]

$$= 70.88 \text{ mm}$$

Factor [α]

$$= t \times e + 1$$

$$= 70.88 \times 0.00849 + 1$$

$$= 1.602$$

Factor [β]

$$= 1.333 \times t \times e + 1$$

$$= 1.333 \times 70.88 \times 0.00849 + 1$$

$$= 1.803$$

Factor [γ]

$$= \alpha / T$$

$$= 1.602 / 1.853$$

$$= 0.865$$

Factor [δ]

$$= t^3 / d$$

$$= 70.88^3 / 290617.3$$

$$= 1.225$$

Factor [λ]

$$= \gamma + \delta$$

$$= 0.865 + 1.225$$

$$= 2.09$$

18. FLANGE STRESSES AS PER APPENDIX 2-7 & 2-8

Equivalent moment [Mmax]

$$= \text{MAX} [M_0, M_0' \times S_{fo} / S_{fa}]$$

$$= \text{MAX} [552403.2, 4981054.6 \times 14.06 / 14.06]$$

$$= 4981054.6 \text{ kgf-mm}$$

Corrected equivalent moment per unit length [M]

$$= M_{\text{max}} \times (C_f / B)$$

$$= 4981054.6 \times (1 / 1256)$$

$$= 3965.8 \text{ kgf}$$

Longitudinal hub stress [SH]

$$= f \times M / (\lambda \times g_1^2)$$

$$= 4.354 \times 3965.8 / (2.09 \times 21^2)$$

$$= 18.74 \text{ kgf/mm}^2 \quad \dots \quad < 1.5 \times S_{fo}$$

Radial flange stress [SR]

$$= \beta \times M / (\lambda \times t^2)$$

$$= 1.602 \times 3965.8 / (2.09 \times 70.88^2)$$

$$= 0.681 \text{ kgf/mm}^2 \quad \dots \quad < S_{fo}$$

Tangential flange stress [ST]

$$= (M \times Y / t^2) - Z \times SR$$

$$= (3965.8 \times 12.8 / 70.88^2) - 6.606 \times 0.681$$

$$= 5.603 \text{ kgf/mm}^2 \quad \dots \quad < S_{fo}$$

Average stress

$$= \text{MAX} [0.5 \times (SH + SR), 0.5 \times (SH + ST)]$$

$$= \text{MAX} [0.5 \times (18.74 + 0.681), 0.5 \times (18.74 + 5.603)]$$

$$= 12.17 \text{ kgf/mm}^2 \quad \dots \quad < S_{fo}$$

19. FLANGE RIGIDITY CHECKING AS PER APPENDIX AS PER 2-14

Modulus of elasticity for flange Efo 20079.7 kgf/mm²

Rigidity factor KI 0.3

Rigidity index [J]

$$= 52.14 \times V \times M_{\max} / (\lambda \times E_{fo} \times g_0^2 \times KI \times h_0)$$

$$= 52.14 \times 0.417 \times 4981054.6 / (2.09 \times 20079.7 \times 9^2 \times 0.3 \times 106.3)$$

$$= 0.998$$

Since $J < 1.0$, design is safe

'CadempVD' Version 18.00 by CADEM Softwares , Pune , Website www.cadem.net

Licensee :

CADEM Softwares, 411003

Customer

ABC Company Ltd.

Project / Equipment

Soap Plant / PV-01 - Gas Filter

Designed By / Revision and Date

/ R00 , 24/Aug/2018 11:17:33

DESIGN OF SHELL (INTERNAL AND EXTERNAL PRESSURE)

Main Shell

CODE

ASME VIII Div.1, 15

1. DESIGN CONDITIONS (Operating Mode , Corroded Condition)

Design pressure (internal)	Pi	0.12 kgf/mm ² g
Design pressure (external)	Pe	0.01055 kgf/mm ² g
Design temperature	T	120 °C
Material of construction		SA-516 GR. 70 Plt. [UNS:K02700]
Max. allowable stress at design temp.	S	14.06 kgf/mm ²
Radiography		Spot
Joint efficiency long. seam	Ec	0.85
Outside diameter	OD	1274 mm
Inside radius (corroded)	R	628 mm
Shell length	L	1650 mm
Design length	L1	1650 mm
Nominal thickness		12 mm
Nominal thickness required as per TEMA		N.A. mm
Internal allowance, corrosion + polishing		3 mm
External allowance, corrosion + polishing		0 mm
Thickness undertolerance		0 mm
Available thickness		9 mm

2. DESIGN CALCULATION AS PER UG-27

$$\begin{aligned} &\text{Thickness of shell under internal pressure [ti]} \\ &= P_i \times R / (S \times E - 0.6 \times P_i) \\ &= 0.12 \times 628 / (14.06 \times 0.85 - 0.6 \times 0.12) \\ &= 6.343 \text{ mm} \end{aligned}$$

3. DESIGN CALCULATION OF SHELL THICKNESS UNDER EXTERNAL PRESSURE AS PER UG-28

Assumed te	4.506 mm
L1 / OD	1.295
OD / te	282.7
Factor A (Refer to Fig. G in Subpart 3 of Sec. II, Part D)	0.00021
Factor B (CS-2)	2.302 kgf/mm ²

$$\begin{aligned} &\text{Allowable external pressure [Pa]} \\ &= 4 \times B / (3 \times (OD / te)) \\ &= 4 \times 2.302 / (3 \times 282.7) \\ &= 0.01086 \text{ kgf/mm}^2 \text{ g} \end{aligned}$$

Since Pa > Pe, design is safe

Since available thickness is more than design thickness, design is safe.

'CadempVD' Version 18.00 by CADEM Softwares , Pune , Website www.cadem.net

Licensee :

CADEM Softwares, 411003

Customer

ABC Company Ltd.

Project / Equipment

Soap Plant / PV-01 - Gas Filter

Designed By / Revision and Date

/ R00 , 24/Aug/2018 11:17:33

DESIGN OF ELLIPSOIDAL HEAD (INT. & EXT. PRESSURE)

Dished End (Rear)

CODE

ASME VIII Div.1, 15

1. DESIGN CONDITIONS (Operating Mode , Corroded Condition) :

Design pressure (internal)	Pi	0.12 kgf/mm ² g
Design pressure (external)	Pe	0.01055 kgf/mm ² g
Design temperature	T	120 °C
Material of construction		SA-516 GR. 70 Plt. [UNS:K02700]
Max. allowable stress @ design temp.	S	14.06 kgf/mm ²
Radiography		Full
Joint efficiency	E	1
Outside diameter of head	OD	1274 mm
Inside diameter of shell	ID	1256 mm
Head shape		Elliptical D/2H = 2.0
Nominal thickness		12 mm
Nominal thickness required as per TEMA		N.A mm
Internal allowance, corrosion + polishing		3 mm
External allowance, corrosion + polishing		0 mm
Thinning allowance / Under tolerance		1.2 mm
Available thickness		7.8 mm

2. DESIGN CALCULATION AS PER UG 32 d / APPENDIX 1-4 (c) :

Factor [K]

= 1

Thickness for internal pressure [t]

$$= K \times P_i \times ID / (2 \times S \times E - 0.2 \times P_i)$$

$$= 1 \times 0.12 \times 1256 / (2 \times 14.06 \times 1 - 0.2 \times 0.12)$$

$$= 5.364 \text{ mm}$$

3. DESIGN CALCULATION AS PER UG 33 d :

Thickness for equivalent internal pressure [t]

$$= K \times 1.67 \times P_e \times ID / (2 \times S \times 1.0 - 0.2 \times 1.67 \times P_e)$$

$$= 1 \times 1.67 \times 0.01055 \times 1256 / (2 \times 14.06 \times 1.0 - 0.2 \times 1.67 \times 0.01055)$$

$$= 0.787 \text{ mm}$$

Factor [Ko]

$$= 0.88$$

Assumed head thickness, [te]

$$= 3.211 \text{ mm}$$

Factor [A]

$$= 0.125 \times t_e / (K_o \times OD)$$

$$= 0.125 \times 3.211 / (0.88 \times 1274)$$

$$= 0.00036$$

Factor with reference to chart (CS-2) [B]

$$= 3.777 \text{ kgf/mm}^2$$

Allowable external pressure [Pa]

$$= B / (K_o \times OD / t_e)$$

$$= 3.777 \times 3.211 / (0.88 \times 1274)$$

$$= 0.01082 \text{ kgf/mm}^2$$

Since Pa > Pe, design is safe

Since available thickness is more than design thickness, design is safe.

'CadempVD' Version 18.00 by CADEM Softwares , Pune , Website www.cadem.net

Licensee :

CADEM Softwares, 411003

Customer

ABC Company Ltd.

Project / Equipment

Soap Plant / PV-01 - Gas Filter

Designed By / Revision and Date

/ R00 , 24/Aug/2018 11:17:33

LUG SUPPORT DESIGN

Lug Support

CODE

P V Design Manual, D.R. Moss

Operating Mode , Corroded Condition

1. LUG DATA :

M.O.C		IS-2062 GR. A Plt.
No. of support	N	4
Base plate width	b1	222 mm
Base plate depth	Lb	200 mm
Thickness of base plate	tb	16 mm
Allowable bending stress	Sb	22.15 kgf/mm ²

2. BOLT DATA :

M.O.C		Commercial CS Bolt
No. of bolt / lug	Nb	1
Bolt diameter	db	20 mm
PCD	D	1598 mm
Diameter of bolt hole		24 mm
Allowable tensile stress	Fs	10.69 kgf/mm ²

3. GUSSET DATA :

Thickness	tg	16 mm
Height	h	190 mm
Gusset angle	θ	51.71
Gusset depth at top	Lc	50 mm
Number of gussets	n	2
Distance between gussets	b	180 mm

4. SHELL DATA :

Material		SA-516 GR. 70 Plt. [UNS:K02700]
OD diameter	OD	1274 mm
Inside diameter	ID	1256 mm
Thickness available	ts	9 mm

5. PAD DATA :

Material		SA-516 GR. 70 Plt. [UNS:K02700]
Thickness	tp	12 mm
Width	W	275 mm
Length	L	272 mm

6. LOAD AND MOMENT (Wind) :

Max. overturning moment	M	791596.4 kgf-mm
Design weight of vessel	Wt	2415.5 kgf

7. DESIGN OF ANCHOR BOLTS :

Total uplift force on bolts [T]
= [4 x M / (D x N)] - Wt / N
= [4 x 791596.4 / (1598 x 4)] - 2415.5 / 4
= -108.5 kgf
Required area of bolts [Am]
= MAX [(T / Fs) , 0]
= MAX [(-108.5 / 10.69) , 0]

$$= 0 \text{ mm}^2$$

Available area of bolts [Ab]

$$= A_r \times N_b \dots\dots\dots \text{ where, } A_r = 217.1 \text{ mm}^2, \text{ is root area of bolt}$$

$$= 217.1 \times 1$$

$$= 217.1 \text{ mm}^2$$

Since $A_b > A_m$, bolts provided are sufficient

8. GUSSET DESIGN :

Reaction force at each support [Q]

$$= [4 \times M / (D \times N)] + W_t / N$$

$$= [4 \times 791596.4 / (1598 \times 4)] + 2415.5 / 4$$

$$= 1099.2 \text{ kgf}$$

Maximum axial force in gusset [P1]

$$= Q / n$$

$$= 1099.2 / 2$$

$$= 549.6 \text{ kgf}$$

Allowable compr. stress in gusset [Sg]

$$= 18000 / [1 + 12 \times (h' / t_g)^2 / 18000] \dots\dots\dots \text{ where, } h' = 242.1 \text{ mm}$$

$$= 18000 / [1 + 12 \times (242.1 / 16)^2 / 18000]$$

$$= 15616.8 \text{ psi}$$

$$= 10.98 \text{ kgf/mm}^2$$

Required thickness of gusset [tg']

$$= 2 \times P_1 \times (3 \times a - L_b) / [S_g \times L_b^2 \times (\sin \theta)^2]$$

$$= 2 \times 549.6 \times (3 \times 150 - 200) / [10.98 \times (200)^2 \times (\sin 51.71)^2]$$

$$= 1.016 \text{ mm}$$

9. BASE PLATE DESIGN :

Bending moment [Mb]

$$= Q \times b_1 / 6$$

$$= 1099.2 \times 222 / 6$$

$$= 40671.8 \text{ kgf-mm}$$

Bearing pressure [bp]

$$= Q / (w \times b_1) \dots\dots\dots \text{ where, } w = 120 \text{ mm}$$

$$= 1099.2 / (120 \times 222)$$

$$= 0.04126 \text{ kgf/mm}^2$$

Bending moment due to bearing pressure [Mb']

$$= b_p \times b^2 / 10$$

$$= 0.04126 \times 180^2 / 10$$

$$= 133.7 \text{ kgf-mm}$$

Required thickness of base plate between chairs [tb']

$$= \text{SQRT} \{ 6 \times \text{MAX} [M_b, M_b'] / [(L_b - d_b) \times S_b] \}$$

$$= \text{SQRT} \{ 6 \times \text{MAX} [40671.8, 133.7] / [(200 - 20) \times 22.15] \}$$

$$= 7.912 \text{ mm}$$

10. CHECK FOR COMPRESSION PLATE :

Equivalent radial load [f]

$$= Q \times a / (n \times h)$$

$$= 1099.2 \times 150 / (2 \times 190)$$

$$= 433.9 \text{ kgf}$$

Angle between supports [α]

$$= 2 \times \pi / N$$

$$= 2 \times \pi / 4$$

$$= 1.571 \text{ rad}$$

Internal bending moment coefficient [Kr]

$$= 0.5 \times [1 / (0.5 \times \alpha) - \cot (0.5 \times \alpha)]$$

$$= 0.5 \times [1 / (0.5 \times 1.571) - \cot (0.5 \times 1.571)]$$

$$= 0.137$$

Internal bending moment [Mc]

$$= 0.5 \times Kr \times f \times OD$$

$$= 0.5 \times 0.137 \times 433.9 \times 1274$$

$$= 37761.8 \text{ kgf-mm}$$

Bending stress induced [fb]

$$= Mo / Zc$$

$$= 37761.8 / 13224.4$$

$$= 2.855 \text{ kgf/mm}^2 \dots\dots\dots < Sb = 22.15 \text{ kgf/mm}^2$$

Since, induced stress fb < allow. stress Sb in shell material, design is safe.

'CadempVD' Version 18.00 by CADEM Softwares , Pune , Website www.cadem.net

Licensee :

CADEM Softwares, 411003

Customer

ABC Company Ltd.

Project / Equipment

Soap Plant / PV-01 - Gas Filter

Designed By / Revision and Date

/ R00 , 24/Aug/2018 11:17:33

LUG SUPPORT DESIGN

Lug Support

CODE

P V Design Manual, D.R. Moss

Operating Mode , Corroded Condition

1. LUG DATA :

M.O.C		IS-2062 GR. A Plt.
No. of support	N	4
Base plate width	b1	222 mm
Base plate depth	Lb	200 mm
Thickness of base plate	tb	16 mm
Allowable bending stress	Sb	22.15 kgf/mm ²

2. BOLT DATA :

M.O.C		Commercial CS Bolt
No. of bolt / lug	Nb	1
Bolt diameter	db	20 mm
PCD	D	1598 mm
Diameter of bolt hole		24 mm
Allowable tensile stress	Fs	10.69 kgf/mm ²

3. GUSSET DATA :

Thickness	tg	16 mm
Height	h	190 mm
Gusset angle	θ	51.71
Gusset depth at top	Lc	50 mm
Number of gussets	n	2
Distance between gussets	b	180 mm

4. SHELL DATA :

Material		SA-516 GR. 70 Plt. [UNS:K02700]
OD diameter	OD	1274 mm
Inside diameter	ID	1256 mm
Thickness available	ts	9 mm

5. PAD DATA :

Material		SA-516 GR. 70 Plt. [UNS:K02700]
Thickness	tp	12 mm
Width	W	275 mm
Length	L	272 mm

6. LOAD AND MOMENT (Seismic) :

Max. overturning moment	M	393227.8 kgf-mm
Design weight of vessel	Wt	4789.1 kgf

7. DESIGN OF ANCHOR BOLTS :

Total uplift force on bolts [T]
= [4 x M / (D x N)] - Wt / N
= [4 x 393227.8 / (1598 x 4)] - 4789.1 / 4
= -951.2 kgf
Required area of bolts [Am]
= MAX [(T / Fs) , 0]
= MAX [(-951.2 / 10.69) , 0]

$$= 0 \text{ mm}^2$$

Available area of bolts [Ab]

$$= A_r \times N_b \dots\dots\dots \text{ where, } A_r = 217.1 \text{ mm}^2, \text{ is root area of bolt}$$

$$= 217.1 \times 1$$

$$= 217.1 \text{ mm}^2$$

Since $A_b > A_m$, bolts provided are sufficient

8. GUSSET DESIGN :

Reaction force at each support [Q]

$$= [4 \times M / (D \times N)] + W_t / N$$

$$= [4 \times 393227.8 / (1598 \times 4)] + 4789.1 / 4$$

$$= 1443.3 \text{ kgf}$$

Maximum axial force in gusset [P1]

$$= Q / n$$

$$= 1443.3 / 2$$

$$= 721.7 \text{ kgf}$$

Allowable compr. stress in gusset [Sg]

$$= 18000 / [1 + 12 \times (h' / t_g)^2 / 18000] \dots\dots\dots \text{ where, } h' = 242.1 \text{ mm}$$

$$= 18000 / [1 + 12 \times (242.1 / 16)^2 / 18000]$$

$$= 15616.8 \text{ psi}$$

$$= 10.98 \text{ kgf/mm}^2$$

Required thickness of gusset [tg']

$$= 2 \times P_1 \times (3 \times a - L_b) / [S_g \times L_b^2 \times (\sin \theta)^2]$$

$$= 2 \times 721.7 \times (3 \times 150 - 200) / [10.98 \times (200)^2 \times (\sin 51.71)^2]$$

$$= 1.334 \text{ mm}$$

9. BASE PLATE DESIGN :

Bending moment [Mb]

$$= Q \times b_1 / 6$$

$$= 1443.3 \times 222 / 6$$

$$= 53403.7 \text{ kgf-mm}$$

Bearing pressure [bp]

$$= Q / (w \times b_1) \dots\dots\dots \text{ where, } w = 120 \text{ mm}$$

$$= 1443.3 / (120 \times 222)$$

$$= 0.05418 \text{ kgf/mm}^2$$

Bending moment due to bearing pressure [Mb']

$$= b_p \times b^2 / 10$$

$$= 0.05418 \times 180^2 / 10$$

$$= 175.5 \text{ kgf-mm}$$

Required thickness of base plate between chairs [tb']

$$= \text{SQRT} \{ 6 \times \text{MAX} [M_b, M_b'] / [(L_b - d_b) \times S_b] \}$$

$$= \text{SQRT} \{ 6 \times \text{MAX} [53403.7, 175.5] / [(200 - 20) \times 22.15] \}$$

$$= 9.067 \text{ mm}$$

10. CHECK FOR COMPRESSION PLATE :

Equivalent radial load [f]

$$= Q \times a / (n \times h)$$

$$= 1443.3 \times 150 / (2 \times 190)$$

$$= 569.7 \text{ kgf}$$

Angle between supports [α]

$$= 2 \times \pi / N$$

$$= 2 \times \pi / 4$$

$$= 1.571 \text{ rad}$$

Internal bending moment coefficient [Kr]

$$= 0.5 \times [1 / (0.5 \times \alpha) - \cot (0.5 \times \alpha)]$$

$$= 0.5 \times [1 / (0.5 \times 1.571) - \cot (0.5 \times 1.571)]$$

$$= 0.137$$

Internal bending moment [Mc]

$$= 0.5 \times Kr \times f \times OD$$

$$= 0.5 \times 0.137 \times 569.7 \times 1274$$

$$= 49582.7 \text{ kgf-mm}$$

Bending stress induced [fb]

$$= Mo / Zc$$

$$= 49582.7 / 13224.4$$

$$= 3.749 \text{ kgf/mm}^2 \dots\dots\dots < Sb = 22.15 \text{ kgf/mm}^2$$

Since, induced stress fb < allow. stress Sb in shell material, design is safe.

'CadempVD' Version 18.00 by CADEM Softwares , Pune , Website www.cadem.net

Licensee : CADEM Softwares, 411003
Customer ABC Company Ltd.
Project / Equipment Soap Plant / PV-01 - Gas Filter
Designed By / Revision and Date / R00 , 24/Aug/2018 11:17:33

NOZZLE NECK THICKNESS AND REINFORCEMENT DESIGN CODE

N 01
ASME VIII Div.1, 15
Operating Mode , Corroded Condition

DESIGN CONDITIONS

Design pressure (internal) Pi 0.12 kgf/mm² g
Design pressure (external) Pe 0.01055 kgf/mm² g
Design temperature T 120 °C

NOZZLE DATA

M.O.C. SA-106 GR. B Smls. Pipe [UNS:K03006]
Allowable stress @ design temperature Sn 12.02 kgf/mm²
Outside diameter OD 168.3 mm
Inside diameter ID 152.3 mm
Maximum chord length D 152.3 mm
Neck thickness (provided) tnp 10.97 mm
Internal allowance , corrosion + polishing CAI 3 mm
External allowance , corrosion + polishing CAE 0
Neck thickness (tnp - CAI - CAE) tn 7.973 mm
Max. under tolerance on thickness Alw 1.372 mm
Available neck thickness (tn - Alw) tc 6.601 mm
Nozzle projection outward (from vessel outer face) Lo 150 mm
Total length of nozzle (Lo + tvp + Addn for curvature) L 156 mm
Connection type Pipe Nozzle
Application type Process Opening
Reinforcement calculation method Isolated Opening
Design as large opening False

SHELL DATA (Main Shell)

M.O.C. SA-516 GR. 70 Plt. [UNS:K02700]
Allowable stress @ design temperature Sv 14.06 kgf/mm²
Inside radius R 628 mm
Thickness t 9 mm
Min. thickness for external pressure tr2 4.506 mm

WELD DATA

Nozzle outside weld W1 10.86 mm

CALCULATION OF NOZZLE NECK THICKNESS AS PER UG-45

Neck thickness for internal pressure , [ta_1]
Formula in Appendix 1-1 , [ta_1]
= (0.5 x Pi x OD) / (Sn x E + 0.4 x Pi)
= (0.5 x 0.12 x 168.3) / (12.02 x 1.0 + 0.4 x 0.12)
= 0.836 mm
Neck thickness for external pressure , [ta_2]
Neck thickness for external pressure as per UG-28
Assumed neck thickness , [ta_2] = 0.552 mm
L / OD = 0.891
OD / ta_2 = 304.7
Factor A = 0.00028
Factor B = 2.99 kgf/mm²

Allowable external pressure , [Pa]

$$= 4 \times B / (3 \times OD / ta_2)$$

$$= 4 \times 2.99 / (3 \times 304.7)$$

$$= 0.01309 \text{ kgf/mm}^2 \text{ g}$$

Shell thickness for internal pressure as per UG-37 & UG-27 , [tr1 = tb_1]

$$= Pi \times R / (Sv \times E - 0.6 \times Pi)$$

$$= 0.12 \times 628 / (14.06 \times 1.0 - 0.6 \times 0.12)$$

$$= 5.387 \text{ mm}$$

Shell thickness considering internal pressure equal to external pressure as per UG-27 , [tb_2]

$$= Pe \times R / (Sv \times E - 0.6 \times Pe)$$

$$= 0.01055 \times 628 / (14.06 \times 1.0 - 0.6 \times 0.01055)$$

$$= 0.471 \text{ mm}$$

Nozzle minimum thickness required as per Table UG-45 , [tb_3]

$$= 6.223 \text{ mm}$$

Minimum thickness of vessel wall required as per UG-16(b) , [t_min]

$$= 1.6 \text{ mm}$$

Neck thk as per UG-45 , [tUG_45]

Thickness , [ta]

$$= \text{MAX} [ta_1 , ta_2 , t_{\text{min}}]$$

$$= \text{MAX} [0.836 , 0.552 , 1.6]$$

$$= 1.6 \text{ mm}$$

Thickness , [tb]

$$= \text{MIN} [tb_3 , \text{MAX} (tb_1 , tb_2 , t_{\text{min}})]$$

$$= \text{MIN} [6.223 , \text{MAX} (5.387 , 5.387 , 1.6)]$$

$$= 5.387 \text{ mm}$$

Thickness , [tUG_45]

$$= \text{MAX} [ta , tb] \dots\dots\dots \text{ for Process Nozzle}$$

$$= ta \dots\dots\dots \text{ for Access Opening}$$

$$= 5.387 \text{ mm} \dots\dots\dots \text{ Process Opening}$$

Since available neck thickness, tc >= tUG_45 , selected neck thickness is adequate.

'CadempVD' Version 18.00 by CADEM Softwares , Pune , Website www.cadem.net

Licensee :

CADEM Softwares, 411003

Customer

ABC Company Ltd.

Project / Equipment

Soap Plant / PV-01 - Gas Filter

Designed By / Revision and Date

/ R00 , 24/Aug/2018 11:17:33

NOZZLE NECK THICKNESS AND REINFORCEMENT DESIGN CODE

N 02

ASME VIII Div.1, 15

Operating Mode , Corroded Condition

DESIGN CONDITIONS

Design pressure (internal)

Pi 0.12 kgf/mm² g

Design pressure (external)

Pe 0.01055 kgf/mm² g

Design temperature

T 120 °C

NOZZLE DATA

M.O.C.

SA-106 GR. B Smls. Pipe
[UNS:K03006]

Allowable stress @ design temperature

Sn 12.02 kgf/mm²

Outside diameter

OD 168.3 mm

Inside diameter

ID 152.3 mm

Maximum chord length

D 152.3 mm

Neck thickness (provided)

tnp 10.97 mm

Internal allowance , corrosion + polishing

CAI 3 mm

External allowance , corrosion + polishing

CAE 0

Neck thickness (tnp - CAI - CAE)

tn 7.973 mm

Max. under tolerance on thickness

Alw 1.372 mm

Available neck thickness (tn - Alw)

tc 6.601 mm

Nozzle projection outward (from vessel outer face)

Lo 150 mm

Total length of nozzle (Lo + tvp + Addn for curvature)

L 156 mm

Connection type

Pipe Nozzle

Application type

Process Opening

Reinforcement calculation method

Isolated Opening

Design as large opening

False

SHELL DATA (Main Shell)

M.O.C.

SA-516 GR. 70 Plt. [UNS:K02700]

Allowable stress @ design temperature

Sv 14.06 kgf/mm²

Inside radius

R 628 mm

Thickness

t 9 mm

Min. thickness for external pressure

tr2 4.506 mm

WELD DATA

Nozzle outside weld

W1 10.86 mm

CALCULATION OF NOZZLE NECK THICKNESS AS PER UG-45

Neck thickness for internal pressure , [ta_1]

Formula in Appendix 1-1 , [ta_1]

$$= (0.5 \times Pi \times OD) / (Sn \times E + 0.4 \times Pi)$$

$$= (0.5 \times 0.12 \times 168.3) / (12.02 \times 1.0 + 0.4 \times 0.12)$$

$$= 0.836 \text{ mm}$$

Neck thickness for external pressure , [ta_2]

Neck thickness for external pressure as per UG-28

Assumed neck thickness , [ta_2] = 0.552 mm

$$L / OD = 0.891$$

$$OD / ta_2 = 304.7$$

$$\text{Factor A} = 0.00028$$

$$\text{Factor B} = 2.99 \text{ kgf/mm}^2$$

Allowable external pressure , [Pa]

$$= 4 \times B / (3 \times OD / ta_2)$$

$$= 4 \times 2.99 / (3 \times 304.7)$$

$$= 0.01309 \text{ kgf/mm}^2 \text{ g}$$

Shell thickness for internal pressure as per UG-37 & UG-27 , [tr1 = tb_1]

$$= Pi \times R / (Sv \times E - 0.6 \times Pi)$$

$$= 0.12 \times 628 / (14.06 \times 1.0 - 0.6 \times 0.12)$$

$$= 5.387 \text{ mm}$$

Shell thickness considering internal pressure equal to external pressure as per UG-27 , [tb_2]

$$= Pe \times R / (Sv \times E - 0.6 \times Pe)$$

$$= 0.01055 \times 628 / (14.06 \times 1.0 - 0.6 \times 0.01055)$$

$$= 0.471 \text{ mm}$$

Nozzle minimum thickness required as per Table UG-45 , [tb_3]

$$= 6.223 \text{ mm}$$

Minimum thickness of vessel wall required as per UG-16(b) , [t_min]

$$= 1.6 \text{ mm}$$

Neck thk as per UG-45 , [tUG_45]

Thickness , [ta]

$$= \text{MAX} [ta_1 , ta_2 , t_{\text{min}}]$$

$$= \text{MAX} [0.836 , 0.552 , 1.6]$$

$$= 1.6 \text{ mm}$$

Thickness , [tb]

$$= \text{MIN} [tb_3 , \text{MAX} (tb_1 , tb_2 , t_{\text{min}})]$$

$$= \text{MIN} [6.223 , \text{MAX} (5.387 , 5.387 , 1.6)]$$

$$= 5.387 \text{ mm}$$

Thickness , [tUG_45]

$$= \text{MAX} [ta , tb] \dots\dots\dots \text{ for Process Nozzle}$$

$$= ta \dots\dots\dots \text{ for Access Opening}$$

$$= 5.387 \text{ mm} \dots\dots\dots \text{ Process Opening}$$

Since available neck thickness, tc >= tUG_45 , selected neck thickness is adequate.

'CadempVD' Version 18.00 by CADEM Softwares , Pune , Website www.cadem.net

Licensee : CADEM Softwares, 411003
Customer ABC Company Ltd.
Project / Equipment Soap Plant / PV-01 - Gas Filter
Designed By / Revision and Date / R00 , 24/Aug/2018 11:17:33

**NOZZLE NECK THICKNESS AND REINFORCEMENT DESIGN
CODE**

N 03
ASME VIII Div.1, 15
**Operating Mode , Corroded
Condition**

DESIGN CONDITIONS

Design pressure (internal) Pi 0.12 kgf/mm² g
Design pressure (external) Pe 0.01055 kgf/mm² g
Design temperature T 120 °C

NOZZLE DATA

M.O.C. SA-106 GR. B Smls. Pipe
[UNS:K03006]
Allowable stress @ design temperature Sn 12.02 kgf/mm²
Outside diameter OD 168.3 mm
Inside diameter ID 137.7 mm
Maximum chord length D 137.7 mm
Neck thickness (provided) tnp 18.26 mm
Internal allowance , corrosion + polishing CAI 3 mm
External allowance , corrosion + polishing CAE 0
Neck thickness (tnp - CAI - CAE) tn 15.26 mm
Max. under tolerance on thickness Alw 2.283 mm
Available neck thickness (tn - Alw) tc 12.98 mm
Nozzle projection outward (from vessel outer face) Lo 150 mm
Nozzle projection inward (from vessel inner face) Li 0 mm
Total length of nozzle (Lo + Li + tnp + Addn for curvature) L 151 mm
Connection type Pipe Nozzle
Application type Process Opening
Reinforcement calculation method Isolated Opening
Design as large opening False

HEAD DATA (Dished End (Rear))

Allowable stress @ design temperature Sv 14.06 kgf/mm²
Inside diameter of head @ head skirt Dsf 1256 mm
D / 2 H for Ellispoidal head 2
Factor from Table UG-37 K1 0.9
Inside diameter of equivalent sphere, K1 x Dsk x 2 ID1 2260.8 mm
Thickness t 7.8 mm
Min. thickness for external pressure tr2 3.211 mm

WELD DATA

Nozzle outside weld W1 11.88 mm

CALCULATION OF NOZZLE NECK THICKNESS AS PER UG-45

Neck thickness for internal pressure , [ta_1]
Formula in Appendix 1-1 , [ta_1]
= (0.5 x Pi x OD) / (Sn x E + 0.4 x Pi)
= (0.5 x 0.12 x 168.3) / (12.02 x 1.0 + 0.4 x 0.12)
= 0.836 mm
Neck thickness for external pressure , [ta_2]
Neck thickness for external pressure as per UG-28

Assumed neck thickness , [ta_2] = 0.538 mm

L / OD = 0.891

OD / ta_2 = 312.9

Factor A = 0.00027

Factor B = 2.878 kgf/mm²

Allowable external pressure , [Pa]

= 4 x B / (3 x OD / ta_2)

= 4 x 2.878 / (3 x 312.9)

= 0.01226 kgf/mm² g

Head thickness for internal pressure as per UG-37 & UG-27(d) , [tr1 = tb_1]

= 0.5 x Pi x ID1 / (2 x Sv x E - 0.2 x Pi)

= 0.5 x 0.12 x 2260.8 / (2 x 14.06 x 1.0 - 0.2 x 0.12)

= 4.828 mm

Head thickness considering internal pressure equal to external pressure per UG-27(d) , [tb_2]

= 0.5 x Pe x ID1 / (2 x Sv x E - 0.2 x Pe)

= 0.5 x 0.01055 x 2260.8 / (2 x 14.06 x 1.0 - 0.2 x 0.01055)

= 0.424 mm

Nozzle minimum thickness required as per Table UG-45 , [tb_3]

= 6.223 mm

Minimum thickness of vessel wall required as per UG-16(b) , [t_min]

= 1.6 mm

Neck thk as per UG-45 , [tUG_45]

Thickness , [ta]

= MAX [ta_1 , ta_2 , t_min]

= MAX [0.836 , 0.538 , 1.6]

= 1.6 mm

Thickness , [tb]

= MIN [tb_3 , MAX (tb_1 , tb_2 , t_min)]

= MIN [6.223 , MAX (4.828 , 0.424 , 1.6)]

= 4.828 mm

Thickness , [tUG_45]

= MAX [ta , tb] for Process Nozzle

= ta for Access Opening

= 4.828 mm Process Opening

Since available neck thickness, tc >= tUG_45 , selected neck thickness is adequate.

'CadempVD' Version 18.00 by CADEM Softwares , Pune , Website www.cadem.net

Licensee :

CADEM Softwares, 411003

Customer

ABC Company Ltd.

Project / Equipment

Soap Plant / PV-01 - Gas Filter

Designed By / Revision and Date

/ R00 , 24/Aug/2018 11:17:33

DESIGN OF LIFTING LUG

Lifting Lugs

CODE

P V Design Manual, D.R. Moss
Design Mode 1 , Uncorroded
Condition

1. LIFTING LUG DATA :

Material		IS-2062 GR. A Plt.
Length of lug	LL	70 mm
Width of lug	A	120 mm
Thickness of lug plate	TL	14 mm
Straight length	B1	10 mm
Radius at tip	R3	35 mm
Pin Hole diameter	D1	40 mm
Lug to vessel weld size	W1	6.216 mm
Min yield stress	Sy	24.61 kgf/mm ²
Allowable tensile stress (2 / 3 x Sy)	St	16.4 kgf/mm ²
Allowable bending stress (1.5 x St)	Sb	22.15 kgf/mm ²
Allowable shear stress (0.6 x St)	Ss	9.843 kgf/mm ²

2. DESIGN LOADS :

Total design lift weight	Wt	2660.6 kgf
Number of lifting lugs	N	2
Jirk load factor	j	1.5

3. CALCULATION OF REFERENCE DIMENSIONS :

Dimension [L1]

$$= LL - B1 - R3$$

$$= 70 - 10 - 35$$

$$= 25 \text{ mm}$$

Dimension [LT]

$$= LL - R3$$

$$= 70 - 35$$

$$= 35 \text{ mm}$$

Angle [θ1]

$$= \text{ATAN} (2 \times L1 / A)$$

$$= \text{ATAN} (2 \times 25 / 120)$$

$$= 0.395 \text{ radians}$$

Dimension [L2]

$$= L1 / \text{SIN} (\theta1)$$

$$= 25 / \text{SIN} (0.395)$$

$$= 65 \text{ mm}$$

Angle [θ2]

$$= \text{ASIN} (R3 / L2)$$

$$= \text{ASIN} (35 / 65)$$

$$= 0.569 \text{ radians}$$

Angle [θ3]

$$= \theta1 + \theta2$$

$$= 0.395 + 0.569$$

$$= 0.963 \text{ radians}$$

Dimension [L3]

$$= R3 / \text{SIN} (\theta3)$$

$$= 35 / \text{SIN} (0.963)$$

$$= 42.62 \text{ mm}$$

4. DESIGN OF LUG PLATE :

Effective design load on each lug [P]

$$= j \times Wt / N$$

$$= 1.5 \times 2660.6 / 2$$

$$= 1998.1 \text{ kgf}$$

Required min. thickness of lug plate for shear [t2]

$$= P / [(R3 - 0.5 \times D1) \times ss]$$

$$= 1998.1 / [(35 - 0.5 \times 40) \times 9.843]$$

$$= 13.53 \text{ mm}$$

Required min. thickness of lug plate for bending [t1]

Required min. thickness of lug plate for tension [t3]

$$\begin{aligned}
&= 6 \times P \times LT / (A^2 \times Sb) \\
&= 6 \times 1998.1 \times 35 / (120^2 \times 22.15) \\
&= 1.316 \text{ mm}
\end{aligned}$$

$$\begin{aligned}
&= P / [(2 \times L3 - D1) \times ss] \\
&= 1998.1 / [(2 \times 42.62 - 40) \times 16.4] \\
&= 2.692 \text{ mm}
\end{aligned}$$

5. CALCULATION OF STRESSES IN LUG PLATE WELDS :

Bending stress in weld [f1]

$$\begin{aligned}
&= 6 \times P \times LT / [2 \times LL^2] \\
&= 6 \times 1998.1 \times 35 / (2 \times 70^2) \\
&= 42.82 \text{ kgf/mm}
\end{aligned}$$

Max. shear stress in weld [f2]

$$\begin{aligned}
&= P / [2 \times A] \\
&= 1998.1 / (2 \times 120) \\
&= 8.326 \text{ kgf/mm}
\end{aligned}$$

Min. Size of lug plate weld [w1]

$$\begin{aligned}
&= \text{MAX} (f1 , 2 \times f2) / (0.707 \times Ss) \\
&= \text{MAX} (42.82 , 2 \times 8.326) / (0.707 \times 9.843) \\
&= 6.153 \text{ mm}
\end{aligned}$$

'CademPVD' Version 18.00 by CADEM Softwares , Pune , Website www.cadem.net

Licensee :

CADEM Softwares, 411003

Customer

ABC Company Ltd.

Project / Equipment

Soap Plant / PV-01 - Gas Filter

Designed By / Revision and Date

/ R00 , 24/Aug/2018 11:17:33

FOUNDATION LOAD DATA

Sr. No.	Mode	Condition	Weight (kgf)		Wind				Seismic	
			Empty	Filled	Shear (kgf)		Moment (kgf-m)		Shear (kgf)	Moment (kgf-m)
					Tran.	Long.	Tran.	Long.		
1	Operating	Corroded	2415.5	4789.1	626.1	626.1	791.6	791.6	433.7	393.2
2	Design1	Corroded	2415.5	4789.1	626.1	626.1	791.6	791.6	433.7	393.2
3	Operating	Uncorroded	2660.6	5009.7	626.1	626.1	751.5	751.5	451.6	404.1
4	Design1	Uncorroded	2660.6	5009.7	626.1	626.1	751.5	751.5	451.6	404.1

'CademPVD' Version 18.00 by CADEM Softwares , Pune , Website www.cadem.net

Licensee :

CADEM Softwares, 411003

Customer

ABC Company Ltd.

Project / Equipment

Soap Plant / PV-01 - Gas Filter

Designed By / Revision and Date

/ R00 , 24/Aug/2018 11:17:33

CENTER OF GRAVITY DATA

Sr. No.	Mode	Condition	Empty		Operating / Filled	
			Wt (kgf)	C.G. (mm)	Wt (kgf)	C.G. (mm)
1	Operating	Corroded	2415.5	1738.9	4789.1	1381.1
2	Design1	Corroded	2415.5	1738.9	4789.1	1381.1
3	Operating	Uncorroded	2660.6	1674.9	5009.7	1369.2
4	Design1	Uncorroded	2660.6	1674.9	5009.7	1369.2

'CademPVD' Version 18.00 by CADEM Softwares , Pune , Website www.cadem.net

Licensee :

CADEM Softwares, 411003

Customer

ABC Company Ltd.

Project / Equipment

Soap Plant / PV-01 - Gas Filter

Designed By / Revision and Date

/ R00 , 24/Aug/2018 11:17:33

Index

Sr. No.	Description	Page No
1	Title page & equipment info	
2	Design data	
3	Material of constructions	
4	Effective Pressures	
5	Weight summary report	
6	Wind load calculations	
7	Seismic load calculations	
8	Design of Bolted Cover (Front)	
9	Design of Bolted Cover (Front)	
10	Design of Shell Flng (Front)	
11	Design of Shell Flng (Front)	
12	Design of Main Shell	
13	Design of Dished End (Rear)	
14	Design of Lug Support	
15	Design of Lug Support	
16	Design of N 01	
17	Design of N 02	
18	Design of N 03	
19	Design of Lifting Lugs	
20	Foundation load data	
21	C.G. Data	

'CadempVD' Version 18.00 by CADEM Softwares , Pune , Website www.cadem.net

Customer	ABC Company Ltd.
Project	Soap Plant
Location	Vapi Site
Plant	Refrigeration Plant

EQUIPMENT INFORMATION :

Design Code	ASME VIII Div.1, 15
Equipment Name	PV-01 - Gas Filter
Equipment Type	Pressure Vessel
Equipment Class	N.A.
Equipment Category	N.A.
Reference Drawing No	---
Service	Other Service
Support Type	Lug Supports

DESIGN & REVIEWAL :

Designed By	
Design Date	24/Aug/2018 11:17:33
Checked By	
Approved By	
Revision	R00

INSPECTION & APPROVAL :

Inspection Agency	---
Reviewed By	---

EQUIPMENT DATA :

Front end	Flat End
Front end flanged	True
Rear end	Dished End
Rear end flanged	False
Shell ID	1250 mm
Shell OD	1274 mm
Length, Shell (W.L. to W.L) / Overall	1650 / 2122.8 mm

OTHER DATA :

Fabricated weight (corr / uncorr)	2415.5 / 2660.6 kgf
Empty weight + external weights (corr / uncorr)	2415.5 / 2660.6 kgf
Estimated operating weight (corr / uncorr)	4789.1 / 5009.7 kgf
Estimated hydrotest weight (corr / uncorr)	4701.6 / 4922.3 kgf

'CadempVD' Version 18.00 by CADEM Softwares , Pune , Website www.cadem.net

Licensee :

CADEM Softwares, 411003

Customer

ABC Company Ltd.

Project / Equipment

Soap Plant / PV-01 - Gas Filter

Designed By / Revision and Date

/ R00 , 24/Aug/2018 11:17:33

VESSEL DESIGN DATA

(1) PROCESS DETAILS :

	MEDIA	DENSITY kg/m ³
Operating	Process	1000
Design1		1000
Design2		
Startup		
Shutdown		
Upset		
Hydrotest	Water	1000
Pneumatic	Air	1.2

(2) PR. : kgf/mm² g

	INT.	EXT.
Operating	0.12	0.01055
Design1	0.15	0.01055
Design2		
Startup		
Shutdown		
Upset		

(3) TEST PR. : kgf/mm² g

	Input Pr	MAWP	MAP
Hydrotest	0.195	0.195	0.195
Pneumatic	0.165	0.165	0.165

(4) TEMPERATURE : °C

	Input	MIN. MDMT	MAX.
Operating	25	25	120
Design1	15	15	150
Design2			
Startup			
Shutdown			
Upset			
Hydrotest	21.67	21.67	45
Pneumatic	21.67	10	45

(5) ALLOWANCES : mm

	INT.	EXT.
Corrosion	3	0
Polishing	0	0

(6) RADIOGRAPHY & JOINT EFFICIENCY :

	RADIOGRAPHY	JOINT EFFICIENCY
Shell	Spot	0.85
Head	Full	1.00

'CademPVD' Version 18.00 by CADEM Softwares , Pune , Website www.cadem.net

Licensee :

CADEM Softwares, 411003

Customer

ABC Company Ltd.

Project / Equipment

Soap Plant / PV-01 - Gas Filter

Designed By / Revision and Date

/ R00 , 24/Aug/2018 11:17:33

VESSEL DESIGN DATA

1. MATERIAL OF CONSTRUCTION :

	Shell side
Shell	SA-516 GR. 70 Plt. [UNS:K02700]
Head	SA-516 GR. 70 Plt. [UNS:K02700]
Body flange	SA-105 Frg. [UNS:K03504]
Body flange cover	SA-105 Frg. [UNS:K03504]
Liner	

2. NOZZLE CONNECTIONS :

	Shell side
Nozzle neck <= NPS 40	SA-106 GR. B Smls. Pipe [UNS:K03006]
Flange	SA-105 Frg. [UNS:K03504]
Cover flange	SA-105 Frg. [UNS:K03504]
Nozzle NPS > 40 & < 200	SA-106 GR. B Smls. Pipe [UNS:K03006]
Flange	SA-105 Frg. [UNS:K03504]
Cover flange	SA-105 Frg. [UNS:K03504]
Nozzle neck >= NPS 200	SA-516 GR. 70 Plt. [UNS:K02700]
Flange	SA-516 GR. 70 Plt. [UNS:K02700]
Cover flange	SA-516 GR. 70 Plt. [UNS:K02700]
Pad flange	SA-516 GR. 70 Plt. [UNS:K02700]
Pad flange cover	SA-516 GR. 70 Plt. [UNS:K02700]
Manhole flange	SA-516 GR. 70 Plt. [UNS:K02700]
Manhole cover	SA-516 GR. 70 Plt. [UNS:K02700]
Reinforcement pad	SA-516 GR. 70 Plt. [UNS:K02700]
External bolt	SA-193 GR. B7 Bolt [UNS:G41400]
External gasket	CAF with suitable binder (3 mm.)
Stiffener	SA-516 GR. 70 Plt. [UNS:K02700]
Lifting lug	IS-2062 GR. A Plt.
Support	IS-2062 GR. A Plt.
Anchor bolt	Commercial CS Bolt

3. INSULATION & CLADDING:

Mat. / Density / Thk.	Rockwool (Mineral Fibre) / 136.2 kg/m ³ / 40 mm
Mat. / Thk.	Al. sheet / 1.191 mm

'CademPVD' Version 18.00 by CADEM Softwares , Pune , Website www.cadem.net

Licensee : CADEM Softwares, 411003

Customer ABC Company Ltd.

Project / Equipment Soap Plant / PV-01 - Gas Filter

Designed By / Revision and Date / R00 , 24/Aug/2018 11:17:33

SUMMARY OF EFFECTIVE DESIGN PRESSURES IN kgf/mm² g VS TEMPERATURE IN °C

Sr. No.	Item name	Temp.	Inside pr.		Liquid pr.	Effective pr.	
			+ve	-ve		+ve	-ve
1	Bolted Cover (Front)	150	0.15	0.01055	0	0.15	0.01055
2	Shell Flng (Front)	150	0.15	0.01055	0	0.15	0.01055
3	Main Shell	150	0.15	0.01055	0	0.15	0.01055
4	Dished End (Rear)	150	0.15	0.01055	0	0.15	0.01055
5							

'CadempVD' Version 18.00 by CADEM Softwares , Pune , Website www.cadem.net

Licensee :

CADEM Softwares, 411003

Customer

ABC Company Ltd.

Project / Equipment

Soap Plant / PV-01 - Gas Filter

Designed By / Revision and Date

/ R00 , 24/Aug/2018 11:17:33

ITEM WISE WEIGHT SUMMARY

Sr.No.	Item name	Item size	Empty wt kgf	Volume m ³	Filled wt kgf
1	Bolted Cover (Front)	Blind Cover - 1463 OD x 84.304 Thk, RF, 1413 PCD, Tgrv = 1.588	1100.8	0	1100.8
2	Shell Flng (Front)	Plate Ring - 1463 OD x 1250 ID x 1413 PCD, RF, 119.522 Thk, Trgv = 1.588	423.7	0	423.7
3	Gasket Flng (Front)	1381.943 OD x 1250 ID, 3.175 Thk	0.1	0	0.1
4	Bolt Flng (Front)	Hex Head Bolt M22 x 240.751 Lg, 56 Nos.	40.57	0	40.57
5	Main Shell	1274 OD x 12 Thk, 1650 Lg	621.4	2.025	2646.3
6	Dished End (Rear)	Elliptical D/2H = 2.0, 1274 OD x 12 Nom / 10.8 Min Thk, SF = 50	203.2	0.317	520.3
7	Bolting Plate	222 Long x 200 Wide x 16 Thk, 4 Nos.	22.5	0	22.5
8	Gusset Plate	200 Long x 190 Wide x 16 Thk, 8 Nos.	38.51	0	38.51
9	Anchor Bolt	Anchor M20 x 200 Lg, 4 Nos.	1.99	0	1.99
10	Support Pad	275 Long x 272 Wide x 12 Thk, 4 Nos.	28.42	0	28.42
11	N 01	ANSIB36.10, 150 NPS Sch.80, 156 Lg	6.697	0.00262	9.32
12	Flange [N 01]	Weld Neck, ANSI B16.5, RF, 150# for 150 NPS Sch 80 Pipe	8.08	0	8.08
13	Gasket [N 01]	150 NPS x 150#, 3.175 Thk	0.1	0	0.1
14	Counter Flng [N 01]	Weld Neck, ANSI B16.5, RF, 150# for 150 NPS Sch 80 Pipe	8.08	0	8.08
15	Reinf [N 01]	292.659 OD x 171.275 ID x 12 Thk	4.202	0	4.202
16	N 02	ANSIB36.10, 150 NPS Sch.80, 156 Lg	6.697	0.00262	9.32
17	Flange [N 02]	Weld Neck, ANSI B16.5, RF, 150# for 150 NPS Sch 80 Pipe	8.08	0	8.08
18	Gasket [N 02]	150 NPS x 150#, 3.175 Thk	0.1	0	0.1
19	Counter Flng [N 02]	Weld Neck, ANSI B16.5, RF, 150# for 150 NPS Sch 80 Pipe	8.08	0	8.08
20	Reinf [N 02]	292.659 OD x 171.275 ID x 12 Thk	4.202	0	4.202
21	N 03	ANSIB36.10, 150 NPS Sch.160, 151 Lg	10.29	0.00206	12.35
22	Flange [N 03]	Weld Neck, ANSI B16.5, RF, 150# for 150 NPS Sch 160 Pipe	9.203	0	9.203

23	Gasket [N 03]	150 NPS x 150#, 3.175 Thk	0.1	0	0.1
24	Bolted Cover [N 03]	Blind Cover, ANSI B16.5, RF, 150# for 150 NPS Pipe	11.56	0	11.56
25	Reinf [N 03]	263.5 OD x 171.275 ID x 12 Thk	2.992	0	2.992
26	Lifting Lugs	120 Long x 70 Wide x 14 Thk, 2 Nos.	1.862	0	1.862
27	Pad (Lifting Lugs)	70 Long x 170 Wide x 8 Thk, 2 Nos.	1.507	0	1.507
28	Insulation	4178.318 W x 3622.804 L, 40 Thk	82.44	0	82.44
29	Cladding	4182.059 W x 3622.804 L, 1.191 Thk	4.993	0	4.993
30					
31					
32					
33					
34					
35					
			Σ 2660.6		Σ 4922.3

'CadempVD' Version 18.00 by CADEM Softwares , Pune , Website www.cadem.net

Licensee : CADEM Softwares, 411003
Customer ABC Company Ltd.
Project / Equipment Soap Plant / PV-01 - Gas Filter
Designed By / Revision and Date / R00 , 24/Aug/2018 11:17:33

WIND LOAD CALCULATION

CODE

Wind [IS:875, 87]

1. DESIGN CONDITIONS (Design Mode 1 , Corroded Condition) :

Basic wind speed	(Section 5.2)	Vb	50 m/s
Expected life of equipment	(Section 5.3.1)		25 Years
Probability factor (Risk coeff)	(Section 5.3.1)	K1	0.902
Terrain category	(Section 5.3.2)		Category 2
Structure class	(Section 5.3.2.2)		Class B
Topography factor	(Section 5.3.3)	K3	1.3
Force coefficient (Shape factor)		Cf	0.8

3. CALCULATION OF FORCES AND MOMENTS:

Equivalent diameter	De	1862 mm
Overall length of equipment	L	2122.8 mm
Height of C.G. of equipment	Hcg	1738.9 mm
Size and height factor	(Section 5.3.2)	K2 0.98
Effective transverse cross sectional area = De x L	A	3952660.7 mm ²
Effective wind speed = K1 x K2 x K3 x Vb	Vz	57.44 m/s
Wind pressure = 6E-08 x Vz ²	Pz	0.0002 kgf/mm ²
Longitudinal force = Cf x A x Pz	F	626.1 kgf
Support elevation	H	474.5 mm
Turning moment = F x (Hcg - H)	M	791596.4 kgf-mm

'CadempVD' Version 18.00 by CADEM Softwares , Pune , Website www.cadem.net

Licensee : CADEM Softwares, 411003
Customer ABC Company Ltd.
Project / Equipment Soap Plant / PV-01 - Gas Filter
Designed By / Revision and Date / R00 , 24/Aug/2018 11:17:33

SEISMIC LOAD CALCULATION

CODE

Seismic [IS:1893, 02]

1. DESIGN CONDITIONS (Design Mode 1 , Corroded Condition) :

Weight of equipment		Wo	4789.1 kgf
Importance factor	(Table-6 , 2002)	I	1.5
Soil profile type			Stiff Soil Profile (SD)
Foundation type			RCC footings + Tie Beams
Damping factor			5
Seismic zone			Zone III
Seismic zone factor	(Table-2 , 2002)	Z	0.16
Response reduction factor	(Table-7 , 2002)	R	2.9
Spectral accelerations coeff.	(Fig. 2 , 2002)	Sa / g	2.5, Use max value
Damping correction factor	(Table-3 , 2002)	Cf	1
Seismic coefficient	(Clause-6.4.2 , 2002)		
	$= 0.5 \times Z \times I \times Cf \times (Sa / g) \times (1 / R)$		
	$= 0.5 \times 0.16 \times 1.5 \times 1 \times$		
	$2.5 \times (1 / 2.9)$	Ah	0.103

2. CALCULATION OF FORCES AND MOMENTS:

Elevation of support		H	474.5 mm
Height of C.G. of equipment		Hcg	1381.1 mm
Seismic base shear force			
	$= Ah \times Wo$		
	$= 0.103 \times 4789.1$	Vb	433.7 kgf
Seismic moment of support			
	$= Vb \times (Hcg - H)$		
	$= 433.7 \times (1381.1 - 474.5)$	M	393227.8 kgf-mm

'CadempVD' Version 18.00 by CADEM Softwares , Pune , Website www.cadem.net

Licensee : CADEM Softwares, 411003
Customer ABC Company Ltd.
Project / Equipment Soap Plant / PV-01 - Gas Filter
Designed By / Revision and Date / R00 , 24/Aug/2018 11:17:33

DESIGN OF FLAT BOLTED HEAD (INTERNAL)

CODE

Bolted Cover (Front)

ASME VIII Div.1, 15

1. DESIGN CONDITIONS (Design Mode 1 , Corroded Condition) :

Design pressure	P	0.15 kgf/mm ² g
Design temperature	T	150 °C
Allowance	CA	3 mm
Groove allowance	Tg	0 mm
Radiography		Full
Joint efficiency	E	1

2. COVER DATA :

M.O.C.		SA-105 Frg. [UNS:K03504]
Code allw. stress @ design temp.	Sfo	14.06 kgf/mm ²
Code allw. stress @ atm. temp.	Sfa	14.06 kgf/mm ²
Young's modulus	Ey	19888.4 kgf/mm ²
Self reinforced		False
Flange OD	A	1463 mm
Thickness provided		84.3 mm
Thickness available		81.3 mm

3. BOLTING DATA :

M.O.C.		SA-193 GR. B7 Bolt [UNS:G41400]
Code allw. stress @ design temp.	Sb	17.58 kgf/mm ²
Code allw. stress @ atm. temp.	Sa	17.58 kgf/mm ²
Bolt PCD	PCD	1413 mm
Bolt dia.	db	22 mm
No. of bolts	nb	56

4. LINER DATA :

M.O.C.		
Liner ID		mm
Liner OD		mm
Liner thk.		mm

5. GASKET DATA :

M.O.C.		CAF with suitable binder (3 mm.)
Gasket seating stress	y	1.125 kgf/mm ²
Gasket factor	m	2
Inside diameter	Gi	1256 mm
Outside diameter	Go	1381.9 mm
Width of gasket	N	62.97 mm
Width of gasket (as per Table 2-5.2)		31.75 mm
Basic gasket seating width (as per Table 2-5.2)	b0	31.49 mm
Effective gasket width (as per Table 2-5.2)	b	14.14 mm
Dia. at load reaction (see Table 2-5.2)	G	1353.7 mm
Pass partition gasket width	Wp	0 mm
Pass partition gasket length	Lp	0 mm
Effective pass partition gasket width	b'	0 mm

6. BOLT LOAD CALCULATIONS AS PER APPENDIX 2-5 (b1) :

Total joint - contact surface compression load [Hp]

$$= 2 \times (\pi \times b \times G + b' \times Lp) \times m \times P$$

$$= 2 \times (\pi \times 14.14 \times 1353.7 + 0 \times 0) \times 2 \times 0.15$$

$$= 36079.2 \text{ kgf}$$

Total hydrostatic end force [H]

$$= 0.25 \times \pi \times G^2 \times P$$

$$= 0.25 \times \pi \times 1353.7^2 \times 0.15$$

$$= 215875.2 \text{ kgf}$$

Minimum required bolt load for operating condition [Wm1]

$$= Hp + H$$

$$= 36079.2 + 215875.2$$

$$= 251954.3 \text{ kgf}$$

7. BOLT LOAD CALCULATIONS AS PER APPENDIX 2-5 (b2) :

Minimum required bolt load for gasket seating [Wm2]

$$= (\pi \times b \times G + b' \times Lp) \times y$$

$$= (\pi \times 14.14 \times 1353.7 + 0 \times 0) \times 1.125$$

$$= 67643.1 \text{ kgf}$$

8. BOLT AREAS AS PER APPENDIX 2-5 (d) :

Total required cross-sectional area of bolts [Am]

$$= \text{MAX} [Wm2 / Sa , Wm1 / Sb] \dots\dots\dots \text{For Internal '+' Pr Design}$$

$$= Wm2 / Sa \dots\dots\dots \text{For External Pr \& Self Sealing Design}$$

$$= 14334.5 \text{ mm}^2$$

Actual bolt area using root diameter [Ab]

$$= 15255.5 \text{ mm}^2$$

Flange design bolt load for the gasket seating [W]

$$= 0.5 \times (Am + Ab) \times Sa \times 1 \dots\dots\dots \text{average bolt area}$$

$$= Ab \times Sa \times 1 \dots\dots\dots \text{full bolt area}$$

$$= 260047.9 \text{ kgf (Avg. bolt area and margin factor of 1)}$$

9. CHECK FOR GASKET CRUSHING :

Minimum gasket width required [Nmin]

$$= Ab \times Sb / (2 \times \pi \times y \times G)$$

$$= 15255.5 \times 17.58 / (2 \times \pi \times 1.125 \times 1353.7)$$

$$= 28.03 \text{ mm}$$

10. DESIGN CALCULATION AS PER UG 34

Self reinforced		False
Factor C is user input		False
Factor C taken from fig. UG 34 or user input	C	0.3
Factor, 2 ^{0.5} for self reinf. cover, otherwise 1	F	1

Required thickness for bolting condition [t]

$$= G \times F \times \text{SQRT} [1.9 \times W \times 0.5 \times (PCD - G) / (Sfa \times E \times G^3)]$$

$$= 1353.7 \times 1 \times \text{SQRT} [1.9 \times 260047.9 \times 0.5 \times (1413 - 1353.7) / (14.06 \times 1 \times 1353.7^3)]$$

$$= 27.75 \text{ mm}$$

Required thickness for operating condition [t]

$$= G \times F \times \text{SQRT} \{ [C \times P / (Sfo \times E)] + 1.9 \times Wm1 \times 0.5 \times (PCD - G) / (Sfo \times E \times G^3) \}$$

$$= 1353.7 \times 1 \times \text{SQRT} \{ [0.3 \times 0.15 / (14.06 \times 1)] + 1.9 \times 251954.3 \times 0.5 \times (1413 - 1353.7) / (14.06 \times 1 \times 1353.7^3) \}$$

$$= 81.3 \text{ mm}$$

'CadempVD' Version 18.00 by CADEM Softwares , Pune , Website www.cadem.net

Licensee : CADEM Softwares, 411003
Customer ABC Company Ltd.
Project / Equipment Soap Plant / PV-01 - Gas Filter
Designed By / Revision and Date / R00 , 24/Aug/2018 11:17:33

DESIGN OF FLAT BOLTED HEAD (EXTERNAL)

CODE

Bolted Cover (Front)

ASME VIII Div.1, 15

1. DESIGN CONDITIONS (Design Mode 1 , Corroded Condition) :

Design pressure	P	0.01055 kgf/mm ² g
Design temperature	T	150 °C
Allowance	CA	3 mm
Groove allowance	Tg	0 mm
Radiography		Full
Joint efficiency	E	1

2. COVER DATA :

M.O.C.		SA-105 Frg. [UNS:K03504]
Code allw. stress @ design temp.	Sfo	14.06 kgf/mm ²
Code allw. stress @ atm. temp.	Sfa	14.06 kgf/mm ²
Young's modulus	Ey	19888.4 kgf/mm ²
Self reinforced		False
Flange OD	A	1463 mm
Thickness provided		84.3 mm
Thickness available		81.3 mm

3. BOLTING DATA :

M.O.C.		SA-193 GR. B7 Bolt [UNS:G41400]
Code allw. stress @ design temp.	Sb	17.58 kgf/mm ²
Code allw. stress @ atm. temp.	Sa	17.58 kgf/mm ²
Bolt PCD	PCD	1413 mm
Bolt dia.	db	22 mm
No. of bolts	nb	56

4. LINER DATA :

M.O.C.		
Liner ID		mm
Liner OD		mm
Liner thk.		mm

5. GASKET DATA :

M.O.C.		CAF with suitable binder (3 mm.)
Gasket seating stress	y	1.125 kgf/mm ²
Gasket factor	m	2
Inside diameter	Gi	1256 mm
Outside diameter	Go	1381.9 mm
Width of gasket	N	62.97 mm
Width of gasket (as per Table 2-5.2)		31.75 mm
Basic gasket seating width (as per Table 2-5.2)	b0	31.49 mm
Effective gasket width (as per Table 2-5.2)	b	14.14 mm
Dia. at load reaction (see Table 2-5.2)	G	1353.7 mm
Pass partition gasket width	Wp	0 mm
Pass partition gasket length	Lp	0 mm
Effective pass partition gasket width	b'	0 mm

6. BOLT LOAD CALCULATIONS AS PER APPENDIX 2-5 (b1) :

Total joint - contact surface compression load [Hp]
 = $2 \times (\pi \times b \times G + b' \times Lp) \times m \times P$
 = $2 \times (\pi \times 14.14 \times 1353.7 + 0 \times 0) \times 2 \times 0.01055$
 = 2536.7 kgf

Total hydrostatic end force [H]
 = $0.25 \times \pi \times G^2 \times P$
 = $0.25 \times \pi \times 1353.7^2 \times 0.01055$
 = 15177.9 kgf

Minimum required bolt load for operating condition [Wm1]
 = Hp + H
 = 2536.7 + 15177.9
 = 17714.6 kgf

7. BOLT LOAD CALCULATIONS AS PER APPENDIX 2-5 (b2) :

Minimum required bolt load for gasket seating [Wm2]
 = $(\pi \times b \times G + b' \times Lp) \times y$
 = $(\pi \times 14.14 \times 1353.7 + 0 \times 0) \times 1.125$
 = 67643.1 kgf

8. BOLT AREAS AS PER APPENDIX 2-5 (d) :

Total required cross-sectional area of bolts [Am]
 = MAX [Wm2 / Sa , Wm1 / Sb] For Internal '+' Pr Design
 = Wm2 / Sa For External Pr & Self Sealing Design
 = 3848.4 mm²

Actual bolt area using root diameter [Ab]
 = 15255.5 mm²

Flange design bolt load for the gasket seating [W]
 = $0.5 \times (Am + Ab) \times Sa \times 1$ average bolt area
 = $Ab \times Sa \times 1$ full bolt area
 = 167892.3 kgf (Avg. bolt area and margin factor of 1)

9. CHECK FOR GASKET CRUSHING :

Minimum gasket width required [Nmin]
 = $Ab \times Sb / (2 \times \pi \times y \times G)$
 = $15255.5 \times 17.58 / (2 \times \pi \times 1.125 \times 1353.7)$
 = 28.03 mm

10. DESIGN CALCULATION AS PER UG 34

Self reinforced		False
Factor C is user input		False
Factor C taken from fig. UG 34 or user input	C	0.3
Factor, $2^{0.5}$ for self reinf. cover, otherwise 1	F	1

Required thickness for bolting condition [t]
 = $G \times F \times \text{SQRT} [1.9 \times W \times 0.5 \times (PCD - G) / (Sfa \times E \times G^3)]$
 = $1353.7 \times 1 \times \text{SQRT} [1.9 \times 167892.3 \times 0.5 \times (1413 - 1353.7) / (14.06 \times 1 \times 1353.7^3)]$
 = 27.75 mm

Required thickness for operating condition [t]
 = $G \times F \times \text{SQRT} \{ [C \times P / (Sfo \times E)] + 1.9 \times Wm1 \times 0.5 \times (PCD - G) / (Sfo \times E \times G^3) \}$
 = $1353.7 \times 1 \times \text{SQRT} \{ [0.3 \times 0.01055 / (14.06 \times 1)] + 1.9 \times 17714.6 \times 0.5 \times (1413 - 1353.7) / (14.06 \times 1 \times 1353.7^3) \}$
 = 34.04 mm

'CadempVD' Version 18.00 by CADEM Softwares , Pune , Website www.cadem.net

Licensee : CADEM Softwares, 411003
Customer ABC Company Ltd.
Project / Equipment Soap Plant / PV-01 - Gas Filter
Designed By / Revision and Date / R00 , 24/Aug/2018 11:17:33

FLANGE DESIGN (INTERNAL)

CODE

Shell Flng (Front)

ASME VIII Div.1, 15

1. DESIGN CONDITIONS (Design Mode 1 , Corroded Condition) :

Design pressure	P	0.15 kgf/mm ² g
Design temperature	T	150 °C
Allowance	CA	3 mm
Groove allowance	Tg	0 mm

2. FLANGE DATA :

M.O.C.		SA-105 Frg. [UNS:K03504]
Code allw. stress @ design temp.	Sfo	14.06 kgf/mm ²
Code allw. stress @ atm. temp.	Sfa	14.06 kgf/mm ²
Inside diameter	B	1256 mm
Outside diameter	A	1463 mm
Hub length	h	12 mm
Thickness (hub end)	g1	21 mm
Thickness (pipe end)	g0	9 mm
Thickness provided		119.5 mm
Thickness available		116.5 mm

3. BOLTING DATA :

M.O.C.		SA-193 GR. B7 Bolt [UNS:G41400]
Code allw. stress @ design temp.	Sb	17.58 kgf/mm ²
Code allw. stress @ atm. temp.	Sa	17.58 kgf/mm ²
Bolt PCD	C	1413 mm
Bolt dia.	db	22 mm
No. of bolts	nb	56

4. LINER DATA :

M.O.C.		
Liner ID		mm
Liner OD		mm
Liner thk.		mm

5. GASKET DATA :

5a. Flange gasket data :

M.O.C.		CAF with suitable binder (3 mm.)
Gasket type		Ring Gasket
Gasket confinement type		Unconfined
Flange face type		Raised Face
Flange gasket surface finish		Serrated (Normal)
Counter flange face type		Raised Face
Counter gasket surface finish		Serrated (Normal)
Applicable gasket sketch in Table 2-5.2		Type 1B
Applicable gasket column in Table 2-5.2		1
Gasket seating stress (refer to Note 1, Table 2-5.1)	y	1.125 kgf/mm ²
Gasket factor (from Table 2-5.1)	m	2
Inside diameter	Gi	1256 mm
Outside diameter	Go	1381.9 mm
Width of gasket (as per Table 2-5.2)	N	62.97 mm

Width of gasket	(as per Table 2-5.2)	w	62.97 mm
Width of raised face or gasket contact width	(as per Table 2-5.2)		31.75 mm
Basic gasket seating width	(as per Table 2-5.2)	b0	31.49 mm
Effective gasket width	(as per Table 2-5.2)	b	14.14 mm
Dia. at load reaction	(see Table 2-5.2)	G	1353.7 mm

5b. Partition groove gasket data (For H.E. body flange) :

M.O.C.		--	
Gasket seating stress	(refer to Note 1, Table 2-5.1)	y'	0 kgf/mm ²
Gasket factor	(from Table 2-5.1)	m'	0
Pass partition gasket width		Wp	0 mm
Pass partition gasket length		Lp	0 mm
Effective pass partition gasket width		b'	0 mm

6. BOLT LOAD CALCULATIONS AS PER APPENDIX 2-5 (b1)

Total joint - contact surface compression load [Hp]
 $= 2 \times (\pi \times b \times G \times m + b' \times Lp \times m') \times P$
 $= 2 \times (\pi \times 14.14 \times 1353.7 \times 2 + 0 \times 0 \times 0) \times 0.15$
 $= 36079.2 \text{ kgf}$
Total hydrostatic end force [H]
 $= 0.25 \times \pi \times G^2 \times P$
 $= 0.25 \times \pi \times 1353.7^2 \times 0.15$
 $= 215875.2 \text{ kgf}$
Minimum required bolt load for operating condition [Wm1a]
 $= Hp + H$
 $= 36079.2 + 215875.2$
 $= 251954.3 \text{ kgf}$
Minimum required bolt load for operating condition [Wm1b]
(from mating flange)
 $= 251954.3 \text{ kgf}$
Governing bolt load for operating condition [Wm1]
 $= \text{MAX} [Wm1a , Wm1b]$
 $= \text{MAX} [251954.3 , 251954.3]$
 $= 251954.3 \text{ kgf}$

7. BOLT LOAD CALCULATION AS PER APPENDIX 2-5 (b2)

Minimum required bolt load for gasket seating [Wm2]
 $= (\pi \times b \times G \times y + b' \times Lp \times y')$
 $= (\pi \times 14.14 \times 1353.7 \times 1.125 + 0 \times 0 \times 0)$
 $= 67643.1 \text{ kgf}$

8. BOLT AREAS AS PER APPENDIX 2-5 (d)

Total required cross-sectional area of bolts [Am]
 $= \text{MAX} [Wm2 / Sa , Wm1 / Sb]$ For Internal '+' Pr Design
 $= Wm2 / Sa$ For External Pr & Self Sealing Design
 $= 14334.5 \text{ mm}^2$
Actual bolt area using root diameter [Ab]
 $= 15255.5 \text{ mm}^2$
Flange design bolt load for the gasket seating [W]
 $= 0.5 \times (Am + Ab) \times Sa \times 1$ average bolt area
 $= Ab \times Sa \times 1$ full bolt area
 $= 260047.9 \text{ kgf}$ (Avg. bolt area and margin factor of 1)

9. CHECK FOR GASKET CRUSHING

Minimum gasket width required [Nmin]
 $= Ab \times Sb / (2 \times \pi \times y \times G)$
 $= 15255.5 \times 17.58 / (2 \times \pi \times 1.125 \times 1353.7)$
 $= 28.03 \text{ mm}$

10. BOLT SPACING CORRECTION FACTOR

As per Brownell & Young or IS 2825,
 $= \text{SQRT} [\text{Bolt spacing} / (2 \times db + t)]$
As per TEMA or BS 5500,
 $= \text{SQRT} [\text{Bolt spacing} / Bmax]$ where,

$$B_{max} = \text{maximum recommended bolt spacing} = 2 \times db + 6 \times t / (m + 0.5)$$

Code Select, $C_f = 1$ (min. equal to 1)

INTEGRAL FLANGE DESIGN

Shell Flng (Front)

11. LOADS AND FORCES DURING OPERATING CONDITION AS PER APPENDIX 2-3

Hydrostatic end force on area inside of flange [HD]

$$\begin{aligned} &= 0.25 \times \pi \times B^2 \times P \\ &= 0.25 \times \pi \times 1256^2 \times 0.15 \\ &= 185849.1 \text{ kgf} \end{aligned}$$

Gasket load (difference between flange design bolt load and total hydrostatic end force) [HG]

$$\begin{aligned} &= W_{m1} - H \\ &= 251954.3 - 215875.2 \\ &= 36079.2 \text{ kgf} \end{aligned}$$

Difference between total hydrostatic end force and hydrostatic end force on area inside of flange [HT]

$$\begin{aligned} &= H - HD \\ &= 215875.2 - 185849.1 \\ &= 30026.1 \text{ kgf} \end{aligned}$$

12. MOMENT ARMS FOR FLANGE LOADS AS PER TABLE 2-6

Radial distance from the bolt circle to intersection of hub and back of flange, as per Appendix 2-3 [R]

$$\begin{aligned} &= 0.5 \times (C - B) - g_1 \\ &= 0.5 \times (1413 - 1256) - 21 \\ &= 57.5 \text{ mm} \end{aligned}$$

Radial distance from the bolt circle to the circle on which HD acts [hD]

$$\begin{aligned} &= R + 0.5 \times g_1 \\ &= 57.5 + 0.5 \times 21 \\ &= 68 \text{ mm} \end{aligned}$$

Radial distance from gasket load reaction to the bolt circle [hG]

$$\begin{aligned} &= 0.5 \times (C - G) \\ &= 0.5 \times (1413 - 1353.7) \\ &= 29.67 \text{ mm} \end{aligned}$$

Radial distance from the bolt circle to the circle on which HT acts [hT]

$$\begin{aligned} &= 0.5 \times (R + g_1 + hG) \\ &= 0.5 \times (57.5 + 21 + 29.67) \\ &= 54.08 \text{ mm} \end{aligned}$$

13. FLANGE MOMENTS UNDER OPERATING CONDITION AS PER APPENDIX 2-6

Component of moment due to HD [MD]

$$\begin{aligned} &= HD \times hD \\ &= 185849.1 \times 68 \\ &= 12637737.5 \text{ kgf-mm} \end{aligned}$$

Component of moment due to HG [MG]

$$\begin{aligned} &= HG \times hG \\ &= 36079.2 \times 29.67 \\ &= 1070402.1 \text{ kgf-mm} \end{aligned}$$

Component of moment due to HT [MT]

$$\begin{aligned} &= HT \times hT \\ &= 30026.1 \times 54.08 \\ &= 1623933.5 \text{ kgf-mm} \end{aligned}$$

Total moment acting on the flange for operating condition [MO]

$$\begin{aligned} &= MD + MG + MT \\ &= 12637737.5 + 1070402.1 + 1623933.5 \\ &= 15332073.2 \text{ kgf-mm} \end{aligned}$$

14. LOADS AND FORCES DURING GASKET SEATING AS PER APPENDIX 2-3

Gasket load for seating condition [HG]

$$\begin{aligned} &= W \\ &= 260047.9 \text{ kgf} \end{aligned}$$

15. MOMENT UNDER GASKET SEATING AS PER APPENDIX 2-6

Total moment acting on the flange for gasket seating [MO']

$$\begin{aligned} &= W \times hG \\ &= 260047.9 \times 29.67 \\ &= 7715141.1 \text{ kgf-mm} \end{aligned}$$

16. SHAPE CONSTANTS

A / B

K 1.165

Flange factors from Fig. 2-7.1

T	1.853
Z	6.606
Y	12.8
U	14.06
	106.3
e	0.00849
F	0.903
V	0.417
	2.333
	0.113
d	290617.3
f	4.354

h0

F / h0

Factor from Fig. 2-7.2

Factor from Fig. 2-7.3

g1 / g0

h / h0

(U / V) x h0 x g0²

Factor from Fig. 2-7.6

17. STRESS FORMULA FACTORS

Assumed thickness [t]

= 116.5 mm

Factor [α]

= t x e + 1

= 116.5 x 0.00849 + 1

= 1.99

Factor [β]

= 1.333 x t x e + 1

= 1.333 x 116.5 x 0.00849 + 1

= 2.319

Factor [γ]

= α / T

= 1.99 / 1.853

= 1.074

Factor [δ]

= t³ / d

= 116.5³ / 290617.3

= 5.444

Factor [λ]

= γ + δ

= 1.074 + 5.444

= 6.518

18. FLANGE STRESSES AS PER APPENDIX 2-7 & 2-8

Equivalent moment [Mmax]

= MAX [MO , MO' x Sfo / Sfa]

= MAX [15332073.2 , 7715141.1 x 14.06 / 14.06]

= 15332073.2 kgf-mm

Corrected equivalent moment per unit length [M]

= Mmax x (Cf / B)

= 15332073.2 x (1 / 1256)

= 12207.1 kgf

Longitudinal hub stress [SH]

= f x M / (λ x g1²)

= 4.354 x 12207.1 / (6.518 x 21²)

= 18.49 kgf/mm² < 1.5 x Sfo

Radial flange stress [SR]

= β x M / (λ x t²)

= 2.319 x 12207.1 / (6.518 x 116.5²)

= 0.32 kgf/mm² < Sfo

Tangential flange stress [ST]

= (M x Y / t²) - Z x SR

= (12207.1 x 12.8 / 116.5²) - 6.606 x 0.32

= 9.391 kgf/mm² < Sfo

Average stress

$$= \text{MAX} [0.5 \times (SH + SR) , 0.5 \times (SH + ST)]$$

$$= \text{MAX} [0.5 \times (18.49 + 0.32) , 0.5 \times (18.49 + 9.391)]$$

$$= 13.94 \text{ kgf/mm}^2 \dots\dots\dots < Sfo$$

19. FLANGE RIGIDITY CHECKING AS PER APPENDIX 2-14

Modulus of elasticity for flange	Efo	19888.4 kgf/mm ²
Rigidity factor	KI	0.3

Rigidity index [J]

$$= 52.14 \times V \times M_{\text{max}} / (\lambda \times Efo \times g_0^2 \times KI \times h_0)$$

$$= 52.14 \times 0.417 \times 15332073.2 / (6.518 \times 19888.4 \times 9^2 \times 0.3 \times 106.3)$$

$$= 0.995$$

Since J < 1.0, design is safe

'CadempVD' Version 18.00 by CADEM Softwares , Pune , Website www.cadem.net

Licensee : CADEM Softwares, 411003
Customer ABC Company Ltd.
Project / Equipment Soap Plant / PV-01 - Gas Filter
Designed By / Revision and Date / R00 , 24/Aug/2018 11:17:33

FLANGE DESIGN (EXTERNAL)

CODE

Shell Flng (Front)

ASME VIII Div.1, 15

1. DESIGN CONDITIONS (Design Mode 1 , Corroded Condition) :

Design pressure	P	0.01055 kgf/mm ² g
Design temperature	T	150 °C
Allowance	CA	3 mm
Groove allowance	Tg	0 mm

2. FLANGE DATA :

M.O.C.		SA-105 Frg. [UNS:K03504]
Code allw. stress @ design temp.	Sfo	14.06 kgf/mm ²
Code allw. stress @ atm. temp.	Sfa	14.06 kgf/mm ²
Inside diameter	B	1256 mm
Outside diameter	A	1463 mm
Hub length	h	12 mm
Thickness (hub end)	g1	21 mm
Thickness (pipe end)	g0	9 mm
Thickness provided		119.5 mm
Thickness available		116.5 mm

3. BOLTING DATA :

M.O.C.		SA-193 GR. B7 Bolt [UNS:G41400]
Code allw. stress @ design temp.	Sb	17.58 kgf/mm ²
Code allw. stress @ atm. temp.	Sa	17.58 kgf/mm ²
Bolt PCD	C	1413 mm
Bolt dia.	db	22 mm
No. of bolts	nb	56

4. LINER DATA :

M.O.C.		
Liner ID		mm
Liner OD		mm
Liner thk.		mm

5. GASKET DATA :

5a. Flange gasket data :

M.O.C.		CAF with suitable binder (3 mm.)
Gasket type		Ring Gasket
Gasket confinement type		Unconfined
Flange face type		Raised Face
Flange gasket surface finish		Serrated (Normal)
Counter flange face type		Raised Face
Counter gasket surface finish		Serrated (Normal)
Applicable gasket sketch in Table 2-5.2		Type 1B
Applicable gasket column in Table 2-5.2		1
Gasket seating stress (refer to Note 1, Table 2-5.1)	y	1.125 kgf/mm ²
Gasket factor (from Table 2-5.1)	m	2
Inside diameter	Gi	1256 mm
Outside diameter	Go	1381.9 mm
Width of gasket (as per Table 2-5.2)	N	62.97 mm

Width of gasket	(as per Table 2-5.2)	w	62.97 mm
Width of raised face or gasket contact width	(as per Table 2-5.2)		31.75 mm
Basic gasket seating width	(as per Table 2-5.2)	b0	31.49 mm
Effective gasket width	(as per Table 2-5.2)	b	14.14 mm
Dia. at load reaction	(see Table 2-5.2)	G	1353.7 mm

5b. Partition groove gasket data (For H.E. body flange) :

M.O.C.			--
Gasket seating stress	(refer to Note 1, Table 2-5.1)	y'	0 kgf/mm ²
Gasket factor	(from Table 2-5.1)	m'	0
Pass partition gasket width		Wp	0 mm
Pass partition gasket length		Lp	0 mm
Effective pass partition gasket width		b'	0 mm

6. BOLT LOAD CALCULATIONS AS PER APPENDIX 2-5 (b1)

Total joint - contact surface compression load [Hp]

$$= 2 \times (\pi \times b \times G \times m + b' \times Lp \times m') \times P$$

$$= 2 \times (\pi \times 14.14 \times 1353.7 \times 2 + 0 \times 0 \times 0) \times 0.01055$$

$$= 2536.7 \text{ kgf}$$

Total hydrostatic end force [H]

$$= 0.25 \times \pi \times G^2 \times P$$

$$= 0.25 \times \pi \times 1353.7^2 \times 0.01055$$

$$= 15177.9 \text{ kgf}$$

Minimum required bolt load for operating condition [Wm1a]

$$= Hp + H$$

$$= 2536.7 + 15177.9$$

$$= 17714.6 \text{ kgf}$$

Minimum required bolt load for operating condition [Wm1b]

(from mating flange)

$$= 17714.6 \text{ kgf}$$

Governing bolt load for operating condition [Wm1]

$$= \text{MAX} [Wm1a , Wm1b]$$

$$= \text{MAX} [17714.6 , 17714.6]$$

$$= 17714.6 \text{ kgf}$$

7. BOLT LOAD CALCULATION AS PER APPENDIX 2-5 (b2)

Minimum required bolt load for gasket seating [Wm2]

$$= (\pi \times b \times G \times y + b' \times Lp \times y')$$

$$= (\pi \times 14.14 \times 1353.7 \times 1.125 + 0 \times 0 \times 0)$$

$$= 67643.1 \text{ kgf}$$

8. BOLT AREAS AS PER APPENDIX 2-5 (d)

Total required cross-sectional area of bolts [Am]

$$= \text{MAX} [Wm2 / Sa , Wm1 / Sb] \dots\dots\dots \text{For Internal '+' Pr Design}$$

$$= Wm2 / Sa \dots\dots\dots \text{For External Pr \& Self Sealing Design}$$

$$= 3848.4 \text{ mm}^2$$

Actual bolt area using root diameter [Ab]

$$= 15255.5 \text{ mm}^2$$

Flange design bolt load for the gasket seating [W]

$$= 0.5 \times (Am + Ab) \times Sa \times 1 \dots\dots\dots \text{average bolt area}$$

$$= Ab \times Sa \times 1 \dots\dots\dots \text{full bolt area}$$

$$= 167892.3 \text{ kgf (Avg. bolt area and margin factor of 1)}$$

9. CHECK FOR GASKET CRUSHING

Minimum gasket width required [Nmin]

$$= Ab \times Sb / (2 \times \pi \times y \times G)$$

$$= 15255.5 \times 17.58 / (2 \times \pi \times 1.125 \times 1353.7)$$

$$= 28.03 \text{ mm}$$

10. BOLT SPACING CORRECTION FACTOR

As per Brownell & Young or IS 2825,

$$= \text{SQRT} [\text{Bolt spacing} / (2 \times db + t)]$$

As per TEMA or BS 5500,

$$= \text{SQRT} [\text{Bolt spacing} / Bmax] \dots\dots\dots \text{where,}$$

$$B_{max} = \text{maximum recommended bolt spacing} = 2 \times db + 6 \times t / (m + 0.5)$$

Code Select, $C_f = 1$ (min. equal to 1)

INTEGRAL FLANGE DESIGN

Shell Flng (Front)

11. LOADS AND FORCES DURING OPERATING CONDITION AS PER APPENDIX 2-3

Hydrostatic end force on area inside of flange [HD]

$$\begin{aligned} &= 0.25 \times \pi \times B^2 \times P \\ &= 0.25 \times \pi \times 1256^2 \times 0.01055 \\ &= 13066.8 \text{ kgf} \end{aligned}$$

Difference between total hydrostatic end force and hydrostatic end force on area inside of flange [HT]

$$\begin{aligned} &= H - HD \\ &= 15177.9 - 13066.8 \\ &= 2111.1 \text{ kgf} \end{aligned}$$

12. MOMENT ARMS FOR FLANGE LOADS AS PER APPENDIX TABLE 2-6

Radial distance from the bolt circle to intersection of hub and back of flange, as per Appendix 2-3 [R]

$$\begin{aligned} &= 0.5 \times (C - B) - g_1 \\ &= 0.5 \times (1413 - 1256) - 21 \\ &= 57.5 \text{ mm} \end{aligned}$$

Radial distance from the bolt circle to the circle on which HD acts [hD]

$$\begin{aligned} &= R + 0.5 \times g_1 \\ &= 57.5 + 0.5 \times 21 \\ &= 68 \text{ mm} \end{aligned}$$

Radial distance from gasket load reaction to the bolt circle [hG]

$$\begin{aligned} &= 0.5 \times (C - G) \\ &= 0.5 \times (1413 - 1353.7) \\ &= 29.67 \text{ mm} \end{aligned}$$

Radial distance from the bolt circle to the circle on which HT acts [hT]

$$\begin{aligned} &= 0.5 \times (R + g_1 + hG) \\ &= 0.5 \times (57.5 + 21 + 29.67) \\ &= 54.08 \text{ mm} \end{aligned}$$

13. FLANGE MOMENTS UNDER OPERATING CONDITION AS PER APPENDIX 2-6

Component of moment due to HD [MD]

$$\begin{aligned} &= HD \times (hD - hG) \\ &= 13066.8 \times (68 - 29.67) \\ &= 500874.5 \text{ kgf-mm} \end{aligned}$$

Component of moment due to HT [MT]

$$\begin{aligned} &= HT \times (hT - hG) \\ &= 2111.1 \times (54.08 - 29.67) \\ &= 51544.3 \text{ kgf-mm} \end{aligned}$$

Total moment acting on the flange for operating condition [MO]

$$\begin{aligned} &= MD + MT \\ &= 500874.5 + 51544.3 \\ &= 552418.8 \text{ kgf-mm} \end{aligned}$$

14. LOADS AND FORCES DURING GASKET SEATING AS PER APPENDIX 2-3

Gasket load for seating condition [HG]

$$\begin{aligned} &= W \\ &= 167892.3 \text{ kgf} \end{aligned}$$

15. MOMENT UNDER GASKET SEATING AS PER APPENDIX 2-6

Total moment acting on the flange for gasket seating [MO']

$$\begin{aligned} &= W \times hG \\ &= 167892.3 \times 29.67 \\ &= 4981054.6 \text{ kgf-mm} \end{aligned}$$

16. SHAPE CONSTANTS

A / B	K	1.165
Flange factors from Fig. 2-7.1	T	1.853
	Z	6.606
	Y	12.8
	U	14.06
h0		106.3
F / h0	e	0.00849

Factor from Fig. 2-7.2	F	0.903
Factor from Fig. 2-7.3	V	0.417
g1 / g0		2.333
h / h0		0.113
(U / V) x h0 x g0 ²	d	290617.3
Factor from Fig. 2-7.6	f	4.354

17. STRESS FORMULA FACTORS

Assumed thickness [t]

$$= 71.38 \text{ mm}$$

Factor [α]

$$= t \times e + 1$$

$$= 71.38 \times 0.00849 + 1$$

$$= 1.606$$

Factor [β]

$$= 1.333 \times t \times e + 1$$

$$= 1.333 \times 71.38 \times 0.00849 + 1$$

$$= 1.808$$

Factor [γ]

$$= \alpha / T$$

$$= 1.606 / 1.853$$

$$= 0.867$$

Factor [δ]

$$= t^3 / d$$

$$= 71.38^3 / 290617.3$$

$$= 1.251$$

Factor [λ]

$$= \gamma + \delta$$

$$= 0.867 + 1.251$$

$$= 2.118$$

18. FLANGE STRESSES AS PER APPENDIX 2-7 & 2-8

Equivalent moment [Mmax]

$$= \text{MAX} [M_0, M_0' \times S_{fo} / S_{fa}]$$

$$= \text{MAX} [552418.8, 4981054.6 \times 14.06 / 14.06]$$

$$= 4981054.6 \text{ kgf-mm}$$

Corrected equivalent moment per unit length [M]

$$= M_{\text{max}} \times (C_f / B)$$

$$= 4981054.6 \times (1 / 1256)$$

$$= 3965.8 \text{ kgf}$$

Longitudinal hub stress [SH]

$$= f \times M / (\lambda \times g_1^2)$$

$$= 4.354 \times 3965.8 / (2.118 \times 21^2)$$

$$= 18.49 \text{ kgf/mm}^2 \quad \dots \quad < 1.5 \times S_{fo}$$

Radial flange stress [SR]

$$= \beta \times M / (\lambda \times t^2)$$

$$= 1.606 \times 3965.8 / (2.118 \times 71.38^2)$$

$$= 0.665 \text{ kgf/mm}^2 \quad \dots \quad < S_{fo}$$

Tangential flange stress [ST]

$$= (M \times Y / t^2) - Z \times SR$$

$$= (3965.8 \times 12.8 / 71.38^2) - 6.606 \times 0.665$$

$$= 5.571 \text{ kgf/mm}^2 \quad \dots \quad < S_{fo}$$

Average stress

$$= \text{MAX} [0.5 \times (SH + SR), 0.5 \times (SH + ST)]$$

$$= \text{MAX} [0.5 \times (18.49 + 0.665), 0.5 \times (18.49 + 5.571)]$$

$$= 12.03 \text{ kgf/mm}^2 \quad \dots \quad < S_{fo}$$

19. FLANGE RIGIDITY CHECKING AS PER APPENDIX AS PER 2-14

Modulus of elasticity for flange	Efo	19888.4 kgf/mm ²
Rigidity factor	KI	0.3

Rigidity index [J]

$$= 52.14 \times V \times M_{\max} / (\lambda \times E_{fo} \times g_0^2 \times KI \times h_0)$$

$$= 52.14 \times 0.417 \times 4981054.6 / (2.118 \times 19888.4 \times 9^2 \times 0.3 \times 106.3)$$

$$= 0.994$$

Since $J < 1.0$, design is safe

'CadempVD' Version 18.00 by CADEM Softwares , Pune , Website www.cadem.net

Licensee : CADEM Softwares, 411003
Customer ABC Company Ltd.
Project / Equipment Soap Plant / PV-01 - Gas Filter
Designed By / Revision and Date / R00 , 24/Aug/2018 11:17:33

DESIGN OF SHELL (INTERNAL AND EXTERNAL PRESSURE)

Main Shell

CODE

ASME VIII Div.1, 15

1. DESIGN CONDITIONS (Design Mode 1 , Corroded Condition)

Design pressure (internal)	Pi	0.15 kgf/mm ² g
Design pressure (external)	Pe	0.01055 kgf/mm ² g
Design temperature	T	150 °C
Material of construction		SA-516 GR. 70 Plt. [UNS:K02700]
Max. allowable stress at design temp.	S	14.06 kgf/mm ²
Radiography		Spot
Joint efficiency long. seam	Ec	0.85
Outside diameter	OD	1274 mm
Inside radius (corroded)	R	628 mm
Shell length	L	1650 mm
Design length	L1	1650 mm
Nominal thickness		12 mm
Nominal thickness required as per TEMA		N.A. mm
Internal allowance, corrosion + polishing		3 mm
External allowance, corrosion + polishing		0 mm
Thickness undertolerance		0 mm
Available thickness		9 mm

2. DESIGN CALCULATION AS PER UG-27

$$\begin{aligned} &\text{Thickness of shell under internal pressure [ti]} \\ &= P_i \times R / (S \times E - 0.6 \times P_i) \\ &= 0.15 \times 628 / (14.06 \times 0.85 - 0.6 \times 0.15) \\ &= 7.941 \text{ mm} \end{aligned}$$

3. DESIGN CALCULATION OF SHELL THICKNESS UNDER EXTERNAL PRESSURE AS PER UG-28

Assumed te	4.506 mm
L1 / OD	1.295
OD / te	282.7
Factor A (Refer to Fig. G in Subpart 3 of Sec. II, Part D)	0.00021
Factor B (CS-2)	2.298 kgf/mm ²

Allowable external pressure [Pa]

$$\begin{aligned} &= 4 \times B / (3 \times (OD / te)) \\ &= 4 \times 2.298 / (3 \times 282.7) \\ &= 0.01084 \text{ kgf/mm}^2 \text{ g} \end{aligned}$$

Since Pa > Pe, design is safe

Since available thickness is more than design thickness, design is safe.

'CadempVD' Version 18.00 by CADEM Softwares , Pune , Website www.cadem.net

Licensee :

CADEM Softwares, 411003

Customer

ABC Company Ltd.

Project / Equipment

Soap Plant / PV-01 - Gas Filter

Designed By / Revision and Date

/ R00 , 24/Aug/2018 11:17:33

DESIGN OF ELLIPSOIDAL HEAD (INT. & EXT. PRESSURE)

Dished End (Rear)

CODE

ASME VIII Div.1, 15

1. DESIGN CONDITIONS (Design Mode 1 , Corroded Condition) :

Design pressure (internal)	Pi	0.15 kgf/mm ² g
Design pressure (external)	Pe	0.01055 kgf/mm ² g
Design temperature	T	150 °C
Material of construction		SA-516 GR. 70 Plt. [UNS:K02700]
Max. allowable stress @ design temp.	S	14.06 kgf/mm ²
Radiography		Full
Joint efficiency	E	1
Outside diameter of head	OD	1274 mm
Inside diameter of shell	ID	1256 mm
Head shape		Elliptical D/2H = 2.0
Nominal thickness		12 mm
Nominal thickness required as per TEMA		N.A mm
Internal allowance, corrosion + polishing		3 mm
External allowance, corrosion + polishing		0 mm
Thinning allowance / Under tolerance		1.2 mm
Available thickness		7.8 mm

2. DESIGN CALCULATION AS PER UG 32 d / APPENDIX 1-4 (c) :

Factor [K]

= 1

Thickness for internal pressure [t]

= $K \times P_i \times ID / (2 \times S \times E - 0.2 \times P_i)$

= $1 \times 0.15 \times 1256 / (2 \times 14.06 \times 1 - 0.2 \times 0.15)$

= 6.706 mm

3. DESIGN CALCULATION AS PER UG 33 d :

Thickness for equivalent internal pressure [t]

= $K \times 1.67 \times P_e \times ID / (2 \times S \times 1.0 - 0.2 \times 1.67 \times P_e)$

= $1 \times 1.67 \times 0.01055 \times 1256 / (2 \times 14.06 \times 1.0 - 0.2 \times 1.67 \times 0.01055)$

= 0.787 mm

Factor [Ko]

= 0.88

Assumed head thickness, [te]

= 3.211 mm

Factor [A]

= $0.125 \times t_e / (K_o \times OD)$

= $0.125 \times 3.211 / (0.88 \times 1274)$

= 0.00036

Factor with reference to chart (CS-2) [B]

= 3.771 kgf/mm²

Allowable external pressure [Pa]

= $B / (K_o \times OD / t_e)$

= $3.771 \times 3.211 / (0.88 \times 1274)$

= 0.0108 kgf/mm²

Since Pa > Pe, design is safe

Since available thickness is more than design thickness, design is safe.

'CadempVD' Version 18.00 by CADEM Softwares , Pune , Website www.cadem.net

Licensee :

CADEM Softwares, 411003

Customer

ABC Company Ltd.

Project / Equipment

Soap Plant / PV-01 - Gas Filter

Designed By / Revision and Date

/ R00 , 24/Aug/2018 11:17:33

LUG SUPPORT DESIGN

Lug Support

CODE

P V Design Manual, D.R. Moss

Design Mode 1 , Corroded Condition

1. LUG DATA :

M.O.C		IS-2062 GR. A Plt.
No. of support	N	4
Base plate width	b1	222 mm
Base plate depth	Lb	200 mm
Thickness of base plate	tb	16 mm
Allowable bending stress	Sb	22.15 kgf/mm ²

2. BOLT DATA :

M.O.C		Commercial CS Bolt
No. of bolt / lug	Nb	1
Bolt diameter	db	20 mm
PCD	D	1598 mm
Diameter of bolt hole		24 mm
Allowable tensile stress	Fs	10.69 kgf/mm ²

3. GUSSET DATA :

Thickness	tg	16 mm
Height	h	190 mm
Gusset angle	θ	51.71
Gusset depth at top	Lc	50 mm
Number of gussets	n	2
Distance between gussets	b	180 mm

4. SHELL DATA :

Material		SA-516 GR. 70 Plt. [UNS:K02700]
OD diameter	OD	1274 mm
Inside diameter	ID	1256 mm
Thickness available	ts	9 mm

5. PAD DATA :

Material		SA-516 GR. 70 Plt. [UNS:K02700]
Thickness	tp	12 mm
Width	W	275 mm
Length	L	272 mm

6. LOAD AND MOMENT (Wind) :

Max. overturning moment	M	791596.4 kgf-mm
Design weight of vessel	Wt	2415.5 kgf

7. DESIGN OF ANCHOR BOLTS :

Total uplift force on bolts [T]
= [4 x M / (D x N)] - Wt / N
= [4 x 791596.4 / (1598 x 4)] - 2415.5 / 4
= -108.5 kgf
Required area of bolts [Am]
= MAX [(T / Fs) , 0]
= MAX [(-108.5 / 10.69) , 0]

$$= 0 \text{ mm}^2$$

Available area of bolts [Ab]

$$= A_r \times N_b \dots\dots\dots \text{ where, } A_r = 217.1 \text{ mm}^2, \text{ is root area of bolt}$$

$$= 217.1 \times 1$$

$$= 217.1 \text{ mm}^2$$

Since $A_b > A_m$, bolts provided are sufficient

8. GUSSET DESIGN :

Reaction force at each support [Q]

$$= [4 \times M / (D \times N)] + W_t / N$$

$$= [4 \times 791596.4 / (1598 \times 4)] + 2415.5 / 4$$

$$= 1099.2 \text{ kgf}$$

Maximum axial force in gusset [P1]

$$= Q / n$$

$$= 1099.2 / 2$$

$$= 549.6 \text{ kgf}$$

Allowable compr. stress in gusset [Sg]

$$= 18000 / [1 + 12 \times (h' / t_g)^2 / 18000] \dots\dots\dots \text{ where, } h' = 242.1 \text{ mm}$$

$$= 18000 / [1 + 12 \times (242.1 / 16)^2 / 18000]$$

$$= 15616.8 \text{ psi}$$

$$= 10.98 \text{ kgf/mm}^2$$

Required thickness of gusset [tg']

$$= 2 \times P_1 \times (3 \times a - L_b) / [S_g \times L_b^2 \times (\sin \theta)^2]$$

$$= 2 \times 549.6 \times (3 \times 150 - 200) / [10.98 \times (200)^2 \times (\sin 51.71)^2]$$

$$= 1.016 \text{ mm}$$

9. BASE PLATE DESIGN :

Bending moment [Mb]

$$= Q \times b_1 / 6$$

$$= 1099.2 \times 222 / 6$$

$$= 40671.8 \text{ kgf-mm}$$

Bearing pressure [bp]

$$= Q / (w \times b_1) \dots\dots\dots \text{ where, } w = 120 \text{ mm}$$

$$= 1099.2 / (120 \times 222)$$

$$= 0.04126 \text{ kgf/mm}^2$$

Bending moment due to bearing pressure [Mb']

$$= b_p \times b^2 / 10$$

$$= 0.04126 \times 180^2 / 10$$

$$= 133.7 \text{ kgf-mm}$$

Required thickness of base plate between chairs [tb']

$$= \text{SQRT} \{ 6 \times \text{MAX} [M_b, M_b'] / [(L_b - d_b) \times S_b] \}$$

$$= \text{SQRT} \{ 6 \times \text{MAX} [40671.8, 133.7] / [(200 - 20) \times 22.15] \}$$

$$= 7.912 \text{ mm}$$

10. CHECK FOR COMPRESSION PLATE :

Equivalent radial load [f]

$$= Q \times a / (n \times h)$$

$$= 1099.2 \times 150 / (2 \times 190)$$

$$= 433.9 \text{ kgf}$$

Angle between supports [α]

$$= 2 \times \pi / N$$

$$= 2 \times \pi / 4$$

$$= 1.571 \text{ rad}$$

Internal bending moment coefficient [Kr]

$$= 0.5 \times [1 / (0.5 \times \alpha) - \cot (0.5 \times \alpha)]$$

$$= 0.5 \times [1 / (0.5 \times 1.571) - \cot (0.5 \times 1.571)]$$

$$= 0.137$$

Internal bending moment [Mc]

$$= 0.5 \times Kr \times f \times OD$$

$$= 0.5 \times 0.137 \times 433.9 \times 1274$$

$$= 37761.8 \text{ kgf-mm}$$

Bending stress induced [fb]

$$= Mo / Zc$$

$$= 37761.8 / 13224.4$$

$$= 2.855 \text{ kgf/mm}^2 \dots\dots\dots < Sb = 22.15 \text{ kgf/mm}^2$$

Since, induced stress fb < allow. stress Sb in shell material, design is safe.

'CadempVD' Version 18.00 by CADEM Softwares , Pune , Website www.cadem.net

Licensee :

CADEM Softwares, 411003

Customer

ABC Company Ltd.

Project / Equipment

Soap Plant / PV-01 - Gas Filter

Designed By / Revision and Date

/ R00 , 24/Aug/2018 11:17:33

LUG SUPPORT DESIGN

Lug Support

CODE

P V Design Manual, D.R. Moss

Design Mode 1 , Corroded Condition

1. LUG DATA :

M.O.C		IS-2062 GR. A Plt.
No. of support	N	4
Base plate width	b1	222 mm
Base plate depth	Lb	200 mm
Thickness of base plate	tb	16 mm
Allowable bending stress	Sb	22.15 kgf/mm ²

2. BOLT DATA :

M.O.C		Commercial CS Bolt
No. of bolt / lug	Nb	1
Bolt diameter	db	20 mm
PCD	D	1598 mm
Diameter of bolt hole		24 mm
Allowable tensile stress	Fs	10.69 kgf/mm ²

3. GUSSET DATA :

Thickness	tg	16 mm
Height	h	190 mm
Gusset angle	θ	51.71
Gusset depth at top	Lc	50 mm
Number of gussets	n	2
Distance between gussets	b	180 mm

4. SHELL DATA :

Material		SA-516 GR. 70 Plt. [UNS:K02700]
OD diameter	OD	1274 mm
Inside diameter	ID	1256 mm
Thickness available	ts	9 mm

5. PAD DATA :

Material		SA-516 GR. 70 Plt. [UNS:K02700]
Thickness	tp	12 mm
Width	W	275 mm
Length	L	272 mm

6. LOAD AND MOMENT (Seismic) :

Max. overturning moment	M	393227.8 kgf-mm
Design weight of vessel	Wt	4789.1 kgf

7. DESIGN OF ANCHOR BOLTS :

Total uplift force on bolts [T]
= [4 x M / (D x N)] - Wt / N
= [4 x 393227.8 / (1598 x 4)] - 4789.1 / 4
= -951.2 kgf
Required area of bolts [Am]
= MAX [(T / Fs) , 0]
= MAX [(-951.2 / 10.69) , 0]

$$= 0 \text{ mm}^2$$

Available area of bolts [Ab]

$$= A_r \times N_b \dots\dots\dots \text{ where, } A_r = 217.1 \text{ mm}^2, \text{ is root area of bolt}$$

$$= 217.1 \times 1$$

$$= 217.1 \text{ mm}^2$$

Since $A_b > A_m$, bolts provided are sufficient

8. GUSSET DESIGN :

Reaction force at each support [Q]

$$= [4 \times M / (D \times N)] + W_t / N$$

$$= [4 \times 393227.8 / (1598 \times 4)] + 4789.1 / 4$$

$$= 1443.3 \text{ kgf}$$

Maximum axial force in gusset [P1]

$$= Q / n$$

$$= 1443.3 / 2$$

$$= 721.7 \text{ kgf}$$

Allowable compr. stress in gusset [Sg]

$$= 18000 / [1 + 12 \times (h' / t_g)^2 / 18000] \dots\dots\dots \text{ where, } h' = 242.1 \text{ mm}$$

$$= 18000 / [1 + 12 \times (242.1 / 16)^2 / 18000]$$

$$= 15616.8 \text{ psi}$$

$$= 10.98 \text{ kgf/mm}^2$$

Required thickness of gusset [tg']

$$= 2 \times P_1 \times (3 \times a - L_b) / [S_g \times L_b^2 \times (\sin \theta)^2]$$

$$= 2 \times 721.7 \times (3 \times 150 - 200) / [10.98 \times (200)^2 \times (\sin 51.71)^2]$$

$$= 1.334 \text{ mm}$$

9. BASE PLATE DESIGN :

Bending moment [Mb]

$$= Q \times b_1 / 6$$

$$= 1443.3 \times 222 / 6$$

$$= 53403.7 \text{ kgf-mm}$$

Bearing pressure [bp]

$$= Q / (w \times b_1) \dots\dots\dots \text{ where, } w = 120 \text{ mm}$$

$$= 1443.3 / (120 \times 222)$$

$$= 0.05418 \text{ kgf/mm}^2$$

Bending moment due to bearing pressure [Mb']

$$= b_p \times b^2 / 10$$

$$= 0.05418 \times 180^2 / 10$$

$$= 175.5 \text{ kgf-mm}$$

Required thickness of base plate between chairs [tb']

$$= \text{SQRT} \{ 6 \times \text{MAX} [M_b, M_b'] / [(L_b - d_b) \times S_b] \}$$

$$= \text{SQRT} \{ 6 \times \text{MAX} [53403.7, 175.5] / [(200 - 20) \times 22.15] \}$$

$$= 9.067 \text{ mm}$$

10. CHECK FOR COMPRESSION PLATE :

Equivalent radial load [f]

$$= Q \times a / (n \times h)$$

$$= 1443.3 \times 150 / (2 \times 190)$$

$$= 569.7 \text{ kgf}$$

Angle between supports [α]

$$= 2 \times \pi / N$$

$$= 2 \times \pi / 4$$

$$= 1.571 \text{ rad}$$

Internal bending moment coefficient [Kr]

$$= 0.5 \times [1 / (0.5 \times \alpha) - \cot (0.5 \times \alpha)]$$

$$= 0.5 \times [1 / (0.5 \times 1.571) - \cot (0.5 \times 1.571)]$$

$$= 0.137$$

Internal bending moment [Mc]

$$= 0.5 \times Kr \times f \times OD$$

$$= 0.5 \times 0.137 \times 569.7 \times 1274$$

$$= 49582.7 \text{ kgf-mm}$$

Bending stress induced [fb]

$$= Mo / Zc$$

$$= 49582.7 / 13224.4$$

$$= 3.749 \text{ kgf/mm}^2 \dots\dots\dots < Sb = 22.15 \text{ kgf/mm}^2$$

Since, induced stress fb < allow. stress Sb in shell material, design is safe.

'CadempVD' Version 18.00 by CADEM Softwares , Pune , Website www.cadem.net

Licensee :

CADEM Softwares, 411003

Customer

ABC Company Ltd.

Project / Equipment

Soap Plant / PV-01 - Gas Filter

Designed By / Revision and Date

/ R00 , 24/Aug/2018 11:17:33

NOZZLE NECK THICKNESS AND REINFORCEMENT DESIGN CODE

N 01

ASME VIII Div.1, 15

Design Mode 1 , Corroded Condition

DESIGN CONDITIONS

Design pressure (internal)

Pi 0.15 kgf/mm² g

Design pressure (external)

Pe 0.01055 kgf/mm² g

Design temperature

T 150 °C

NOZZLE DATA

M.O.C.

SA-106 GR. B Smls. Pipe
[UNS:K03006]

Allowable stress @ design temperature

Sn 12.02 kgf/mm²

Outside diameter

OD 168.3 mm

Inside diameter

ID 152.3 mm

Maximum chord length

D 152.3 mm

Neck thickness (provided)

tnp 10.97 mm

Internal allowance , corrosion + polishing

CAI 3 mm

External allowance , corrosion + polishing

CAE 0

Neck thickness (tnp - CAI - CAE)

tn 7.973 mm

Max. under tolerance on thickness

Alw 1.372 mm

Available neck thickness (tn - Alw)

tc 6.601 mm

Nozzle projection outward (from vessel outer face)

Lo 150 mm

Total length of nozzle (Lo + tvp + Addn for curvature)

L 156 mm

Connection type

Pipe Nozzle

Application type

Process Opening

Reinforcement calculation method

Isolated Opening

Design as large opening

False

SHELL DATA (Main Shell)

M.O.C.

SA-516 GR. 70 Plt. [UNS:K02700]

Allowable stress @ design temperature

Sv 14.06 kgf/mm²

Inside radius

R 628 mm

Thickness

t 9 mm

Min. thickness for external pressure

tr2 4.506 mm

WELD DATA

Nozzle outside weld

W1 10.86 mm

CALCULATION OF NOZZLE NECK THICKNESS AS PER UG-45

Neck thickness for internal pressure , [ta_1]

Formula in Appendix 1-1 , [ta_1]

$$= (0.5 \times Pi \times OD) / (Sn \times E + 0.4 \times Pi)$$

$$= (0.5 \times 0.15 \times 168.3) / (12.02 \times 1.0 + 0.4 \times 0.15)$$

$$= 1.045 \text{ mm}$$

Neck thickness for external pressure , [ta_2]

Neck thickness for external pressure as per UG-28

Assumed neck thickness , [ta_2] = 0.552 mm

$$L / OD = 0.891$$

$$OD / ta_2 = 304.7$$

$$\text{Factor A} = 0.00028$$

$$\text{Factor B} = 2.985 \text{ kgf/mm}^2$$

Allowable external pressure , [Pa]

$$= 4 \times B / (3 \times OD / ta_2)$$

$$= 4 \times 2.985 / (3 \times 304.7)$$

$$= 0.01306 \text{ kgf/mm}^2 \text{ g}$$

Shell thickness for internal pressure as per UG-37 & UG-27 , [tr1 = tb_1]

$$= Pi \times R / (Sv \times E - 0.6 \times Pi)$$

$$= 0.15 \times 628 / (14.06 \times 1.0 - 0.6 \times 0.15)$$

$$= 6.742 \text{ mm}$$

Shell thickness considering internal pressure equal to external pressure as per UG-27 , [tb_2]

$$= Pe \times R / (Sv \times E - 0.6 \times Pe)$$

$$= 0.01055 \times 628 / (14.06 \times 1.0 - 0.6 \times 0.01055)$$

$$= 0.471 \text{ mm}$$

Nozzle minimum thickness required as per Table UG-45 , [tb_3]

$$= 6.223 \text{ mm}$$

Minimum thickness of vessel wall required as per UG-16(b) , [t_min]

$$= 1.6 \text{ mm}$$

Neck thk as per UG-45 , [tUG_45]

Thickness , [ta]

$$= \text{MAX} [ta_1 , ta_2 , t_{\text{min}}]$$

$$= \text{MAX} [1.045 , 0.552 , 1.6]$$

$$= 1.6 \text{ mm}$$

Thickness , [tb]

$$= \text{MIN} [tb_3 , \text{MAX} (tb_1 , tb_2 , t_{\text{min}})]$$

$$= \text{MIN} [6.223 , \text{MAX} (6.742 , 6.223 , 1.6)]$$

$$= 6.223 \text{ mm}$$

Thickness , [tUG_45]

$$= \text{MAX} [ta , tb] \dots\dots\dots \text{ for Process Nozzle}$$

$$= ta \dots\dots\dots \text{ for Access Opening}$$

$$= 6.223 \text{ mm} \dots\dots\dots \text{ Process Opening}$$

Since available neck thickness, tc >= tUG_45 , selected neck thickness is adequate.

'CadempVD' Version 18.00 by CADEM Softwares , Pune , Website www.cadem.net

Licensee :

CADEM Softwares, 411003

Customer

ABC Company Ltd.

Project / Equipment

Soap Plant / PV-01 - Gas Filter

Designed By / Revision and Date

/ R00 , 24/Aug/2018 11:17:33

NOZZLE NECK THICKNESS AND REINFORCEMENT DESIGN CODE

N 02

ASME VIII Div.1, 15

Design Mode 1 , Corroded Condition

DESIGN CONDITIONS

Design pressure (internal)

Pi 0.15 kgf/mm² g

Design pressure (external)

Pe 0.01055 kgf/mm² g

Design temperature

T 150 °C

NOZZLE DATA

M.O.C.

SA-106 GR. B Smls. Pipe
[UNS:K03006]

Allowable stress @ design temperature

Sn 12.02 kgf/mm²

Outside diameter

OD 168.3 mm

Inside diameter

ID 152.3 mm

Maximum chord length

D 152.3 mm

Neck thickness (provided)

tnp 10.97 mm

Internal allowance , corrosion + polishing

CAI 3 mm

External allowance , corrosion + polishing

CAE 0

Neck thickness (tnp - CAI - CAE)

tn 7.973 mm

Max. under tolerance on thickness

Alw 1.372 mm

Available neck thickness (tn - Alw)

tc 6.601 mm

Nozzle projection outward (from vessel outer face)

Lo 150 mm

Total length of nozzle (Lo + tvp + Addn for curvature)

L 156 mm

Connection type

Pipe Nozzle

Application type

Process Opening

Reinforcement calculation method

Isolated Opening

Design as large opening

False

SHELL DATA (Main Shell)

M.O.C.

SA-516 GR. 70 Plt. [UNS:K02700]

Allowable stress @ design temperature

Sv 14.06 kgf/mm²

Inside radius

R 628 mm

Thickness

t 9 mm

Min. thickness for external pressure

tr2 4.506 mm

WELD DATA

Nozzle outside weld

W1 10.86 mm

CALCULATION OF NOZZLE NECK THICKNESS AS PER UG-45

Neck thickness for internal pressure , [ta_1]

Formula in Appendix 1-1 , [ta_1]

$$= (0.5 \times Pi \times OD) / (Sn \times E + 0.4 \times Pi)$$

$$= (0.5 \times 0.15 \times 168.3) / (12.02 \times 1.0 + 0.4 \times 0.15)$$

$$= 1.045 \text{ mm}$$

Neck thickness for external pressure , [ta_2]

Neck thickness for external pressure as per UG-28

Assumed neck thickness , [ta_2] = 0.552 mm

$$L / OD = 0.891$$

$$OD / ta_2 = 304.7$$

$$\text{Factor A} = 0.00028$$

$$\text{Factor B} = 2.985 \text{ kgf/mm}^2$$

Allowable external pressure , [Pa]

$$= 4 \times B / (3 \times OD / ta_2)$$

$$= 4 \times 2.985 / (3 \times 304.7)$$

$$= 0.01306 \text{ kgf/mm}^2 \text{ g}$$

Shell thickness for internal pressure as per UG-37 & UG-27 , [tr1 = tb_1]

$$= Pi \times R / (Sv \times E - 0.6 \times Pi)$$

$$= 0.15 \times 628 / (14.06 \times 1.0 - 0.6 \times 0.15)$$

$$= 6.742 \text{ mm}$$

Shell thickness considering internal pressure equal to external pressure as per UG-27 , [tb_2]

$$= Pe \times R / (Sv \times E - 0.6 \times Pe)$$

$$= 0.01055 \times 628 / (14.06 \times 1.0 - 0.6 \times 0.01055)$$

$$= 0.471 \text{ mm}$$

Nozzle minimum thickness required as per Table UG-45 , [tb_3]

$$= 6.223 \text{ mm}$$

Minimum thickness of vessel wall required as per UG-16(b) , [t_min]

$$= 1.6 \text{ mm}$$

Neck thk as per UG-45 , [tUG_45]

Thickness , [ta]

$$= \text{MAX} [ta_1 , ta_2 , t_{\text{min}}]$$

$$= \text{MAX} [1.045 , 0.552 , 1.6]$$

$$= 1.6 \text{ mm}$$

Thickness , [tb]

$$= \text{MIN} [tb_3 , \text{MAX} (tb_1 , tb_2 , t_{\text{min}})]$$

$$= \text{MIN} [6.223 , \text{MAX} (6.742 , 6.223 , 1.6)]$$

$$= 6.223 \text{ mm}$$

Thickness , [tUG_45]

$$= \text{MAX} [ta , tb] \dots\dots\dots \text{ for Process Nozzle}$$

$$= ta \dots\dots\dots \text{ for Access Opening}$$

$$= 6.223 \text{ mm} \dots\dots\dots \text{ Process Opening}$$

Since available neck thickness, tc >= tUG_45 , selected neck thickness is adequate.

'CadempVD' Version 18.00 by CADEM Softwares , Pune , Website www.cadem.net

Licensee : CADEM Softwares, 411003
Customer ABC Company Ltd.
Project / Equipment Soap Plant / PV-01 - Gas Filter
Designed By / Revision and Date / R00 , 24/Aug/2018 11:17:33

NOZZLE NECK THICKNESS AND REINFORCEMENT DESIGN CODE

N 03
ASME VIII Div.1, 15
Design Mode 1 , Corroded Condition

DESIGN CONDITIONS

Design pressure (internal) Pi 0.15 kgf/mm² g
Design pressure (external) Pe 0.01055 kgf/mm² g
Design temperature T 150 °C

NOZZLE DATA

M.O.C. SA-106 GR. B Smls. Pipe [UNS:K03006]
Allowable stress @ design temperature Sn 12.02 kgf/mm²
Outside diameter OD 168.3 mm
Inside diameter ID 137.7 mm
Maximum chord length D 137.7 mm
Neck thickness (provided) tnp 18.26 mm
Internal allowance , corrosion + polishing CAI 3 mm
External allowance , corrosion + polishing CAE 0
Neck thickness (tnp - CAI - CAE) tn 15.26 mm
Max. under tolerance on thickness Alw 2.283 mm
Available neck thickness (tn - Alw) tc 12.98 mm
Nozzle projection outward (from vessel outer face) Lo 150 mm
Nozzle projection inward (from vessel inner face) Li 0 mm
Total length of nozzle (Lo + Li + tnp + Addn for curvature) L 151 mm
Connection type Pipe Nozzle
Application type Process Opening
Reinforcement calculation method Isolated Opening
Design as large opening False

HEAD DATA (Dished End (Rear))

Allowable stress @ design temperature Sv 14.06 kgf/mm²
Inside diameter of head @ head skirt Dsf 1256 mm
D / 2 H for Ellispoidal head 2
Factor from Table UG-37 K1 0.9
Inside diameter of equivalent sphere, K1 x Dsk x 2 ID1 2260.8 mm
Thickness t 7.8 mm
Min. thickness for external pressure tr2 3.211 mm

WELD DATA

Nozzle outside weld W1 11.88 mm

CALCULATION OF NOZZLE NECK THICKNESS AS PER UG-45

Neck thickness for internal pressure , [ta_1]
Formula in Appendix 1-1 , [ta_1]
= (0.5 x Pi x OD) / (Sn x E + 0.4 x Pi)
= (0.5 x 0.15 x 168.3) / (12.02 x 1.0 + 0.4 x 0.15)
= 1.045 mm
Neck thickness for external pressure , [ta_2]
Neck thickness for external pressure as per UG-28

Assumed neck thickness , [ta_2] = 0.538 mm

L / OD = 0.891

OD / ta_2 = 312.9

Factor A = 0.00027

Factor B = 2.872 kgf/mm²

Allowable external pressure , [Pa]

= 4 x B / (3 x OD / ta_2)

= 4 x 2.872 / (3 x 312.9)

= 0.01224 kgf/mm² g

Head thickness for internal pressure as per UG-37 & UG-27(d) , [tr1 = tb_1]

= 0.5 x Pi x ID1 / (2 x Sv x E - 0.2 x Pi)

= 0.5 x 0.15 x 2260.8 / (2 x 14.06 x 1.0 - 0.2 x 0.15)

= 6.036 mm

Head thickness considering internal pressure equal to external pressure per UG-27(d) , [tb_2]

= 0.5 x Pe x ID1 / (2 x Sv x E - 0.2 x Pe)

= 0.5 x 0.01055 x 2260.8 / (2 x 14.06 x 1.0 - 0.2 x 0.01055)

= 0.424 mm

Nozzle minimum thickness required as per Table UG-45 , [tb_3]

= 6.223 mm

Minimum thickness of vessel wall required as per UG-16(b) , [t_min]

= 1.6 mm

Neck thk as per UG-45 , [tUG_45]

Thickness , [ta]

= MAX [ta_1 , ta_2 , t_min]

= MAX [1.045 , 0.538 , 1.6]

= 1.6 mm

Thickness , [tb]

= MIN [tb_3 , MAX (tb_1 , tb_2 , t_min)]

= MIN [6.223 , MAX (6.036 , 0.424 , 1.6)]

= 6.036 mm

Thickness , [tUG_45]

= MAX [ta , tb] for Process Nozzle

= ta for Access Opening

= 6.036 mm Process Opening

Since available neck thickness, tc >= tUG_45 , selected neck thickness is adequate.

'CadempVD' Version 18.00 by CADEM Softwares , Pune , Website www.cadem.net

Licensee :

CADEM Softwares, 411003

Customer

ABC Company Ltd.

Project / Equipment

Soap Plant / PV-01 - Gas Filter

Designed By / Revision and Date

/ R00 , 24/Aug/2018 11:17:33

DESIGN OF LIFTING LUG

Lifting Lugs

CODE

P V Design Manual, D.R. Moss
Design Mode 1 , Uncorroded
Condition

1. LIFTING LUG DATA :

Material		IS-2062 GR. A Plt.
Length of lug	LL	70 mm
Width of lug	A	120 mm
Thickness of lug plate	TL	14 mm
Straight length	B1	10 mm
Radius at tip	R3	35 mm
Pin Hole diameter	D1	40 mm
Lug to vessel weld size	W1	6.216 mm
Min yield stress	Sy	24.61 kgf/mm ²
Allowable tensile stress (2 / 3 x Sy)	St	16.4 kgf/mm ²
Allowable bending stress (1.5 x St)	Sb	22.15 kgf/mm ²
Allowable shear stress (0.6 x St)	Ss	9.843 kgf/mm ²

2. DESIGN LOADS :

Total design lift weight	Wt	2660.6 kgf
Number of lifting lugs	N	2
Jirk load factor	j	1.5

3. CALCULATION OF REFERENCE DIMENSIONS :

Dimension [L1]

$$= LL - B1 - R3$$

$$= 70 - 10 - 35$$

$$= 25 \text{ mm}$$

Dimension [LT]

$$= LL - R3$$

$$= 70 - 35$$

$$= 35 \text{ mm}$$

Angle [θ1]

$$= \text{ATAN} (2 \times L1 / A)$$

$$= \text{ATAN} (2 \times 25 / 120)$$

$$= 0.395 \text{ radians}$$

Dimension [L2]

$$= L1 / \text{SIN} (\theta1)$$

$$= 25 / \text{SIN} (0.395)$$

$$= 65 \text{ mm}$$

Angle [θ2]

$$= \text{ASIN} (R3 / L2)$$

$$= \text{ASIN} (35 / 65)$$

$$= 0.569 \text{ radians}$$

Angle [θ3]

$$= \theta1 + \theta2$$

$$= 0.395 + 0.569$$

$$= 0.963 \text{ radians}$$

Dimension [L3]

$$= R3 / \text{SIN} (\theta3)$$

$$= 35 / \text{SIN} (0.963)$$

$$= 42.62 \text{ mm}$$

4. DESIGN OF LUG PLATE :

Effective design load on each lug [P]

$$= j \times Wt / N$$

$$= 1.5 \times 2660.6 / 2$$

$$= 1998.1 \text{ kgf}$$

Required min. thickness of lug plate for shear [t2]

$$= P / [(R3 - 0.5 \times D1) \times ss]$$

$$= 1998.1 / [(35 - 0.5 \times 40) \times 9.843]$$

$$= 13.53 \text{ mm}$$

Required min. thickness of lug plate for bending [t1]

Required min. thickness of lug plate for tension [t3]

$$\begin{aligned}
&= 6 \times P \times LT / (A^2 \times Sb) \\
&= 6 \times 1998.1 \times 35 / (120^2 \times 22.15) \\
&= 1.316 \text{ mm}
\end{aligned}$$

$$\begin{aligned}
&= P / [(2 \times L3 - D1) \times ss] \\
&= 1998.1 / [(2 \times 42.62 - 40) \times 16.4] \\
&= 2.692 \text{ mm}
\end{aligned}$$

5. CALCULATION OF STRESSES IN LUG PLATE WELDS :

Bending stress in weld [f1]

$$\begin{aligned}
&= 6 \times P \times LT / [2 \times LL^2] \\
&= 6 \times 1998.1 \times 35 / (2 \times 70^2) \\
&= 42.82 \text{ kgf/mm}
\end{aligned}$$

Max. shear stress in weld [f2]

$$\begin{aligned}
&= P / [2 \times A] \\
&= 1998.1 / (2 \times 120) \\
&= 8.326 \text{ kgf/mm}
\end{aligned}$$

Min. Size of lug plate weld [w1]

$$\begin{aligned}
&= \text{MAX} (f1 , 2 \times f2) / (0.707 \times Ss) \\
&= \text{MAX} (42.82 , 2 \times 8.326) / (0.707 \times 9.843) \\
&= 6.153 \text{ mm}
\end{aligned}$$

'CademPVD' Version 18.00 by CADEM Softwares , Pune , Website www.cadem.net

Licensee :

CADEM Softwares, 411003

Customer

ABC Company Ltd.

Project / Equipment

Soap Plant / PV-01 - Gas Filter

Designed By / Revision and Date

/ R00 , 24/Aug/2018 11:17:33

FOUNDATION LOAD DATA

Sr. No.	Mode	Condition	Weight (kgf)		Wind				Seismic	
			Empty	Filled	Shear (kgf)		Moment (kgf- m)		Shear (kgf)	Moment (kgf- m)
					Tran.	Long.	Tran.	Long.		
1	Operating	Corroded	2415.5	4789.1	626.1	626.1	791.6	791.6	433.7	393.2
2	Design1	Corroded	2415.5	4789.1	626.1	626.1	791.6	791.6	433.7	393.2
3	Operating	Uncorroded	2660.6	5009.7	626.1	626.1	751.5	751.5	451.6	404.1
4	Design1	Uncorroded	2660.6	5009.7	626.1	626.1	751.5	751.5	451.6	404.1

'CademPVD' Version 18.00 by CADEM Softwares , Pune , Website www.cadem.net

Licensee :

CADEM Softwares, 411003

Customer

ABC Company Ltd.

Project / Equipment

Soap Plant / PV-01 - Gas Filter

Designed By / Revision and Date

/ R00 , 24/Aug/2018 11:17:33

CENTER OF GRAVITY DATA

Sr. No.	Mode	Condition	Empty		Operating / Filled	
			Wt (kgf)	C.G. (mm)	Wt (kgf)	C.G. (mm)
1	Operating	Corroded	2415.5	1738.9	4789.1	1381.1
2	Design1	Corroded	2415.5	1738.9	4789.1	1381.1
3	Operating	Uncorroded	2660.6	1674.9	5009.7	1369.2
4	Design1	Uncorroded	2660.6	1674.9	5009.7	1369.2